

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction SE SW 1/4 NW 1/4 SW 1/4	Section number 31	Township number T 26 S R 1E E/W	Range number
2. Distance and direction from nearest town or city: 3200 North Sedgwick Street address of well location if in city: Wichita, Kansas			3. Owner of well: James Sheets R.R. or street: 3200 North Sedgwick City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. <u>11</u> in. Completion date <u>6-30-77</u> Well depth <u>41</u> ft.
Topsoil			0	3	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay			3	10	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine Sand			10	18	9. Casing: Material <u>Styrene</u> Height: Above or below <u>11</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>12</u> lbs./ft. Dia. <u>5</u> in. to <u>41</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>41</u> ft. depth gauge No. <u>200</u>
Medium Sand			18	41	10. Screen: Manufacturer's name <u>Sunflower Plastic</u> Type <u>Styrene</u> Dia. <u>5"</u> Slot <u>1/16"</u> Length <u>20'</u> Set between <u>21</u> ft. and <u>41</u> ft. <u>21</u> ft. and <u>41</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>
					11. Static water level: <u>15</u> ft. below land surface Date <u>6-30-77</u> mo./day/yr.
					12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.
					13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u> </u> No Date <u> </u>
					14. Well head completion: <u>Capped</u> <u> </u> Pitless adapter <u>12</u> inches above grade
					15. Well grouted? <u>yes</u> to <u>2</u> fine sand mix. With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>40"</u> ft. to <u>14</u> ft.
					16. Nearest source of possible contamination: <u>City</u> ft. <u>85</u> Direction <u>South</u> Type <u>Sewer</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <u> </u> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other
					(Use a second sheet if needed)
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Harp Well & Pump</u> <u>236</u> Business name License No. Address <u>Wichita, Kansas</u> Signed <u>m. Arnold</u> Date <u>7-28-77</u> Authorized representative		
Topography: <u> </u> Hill <u> </u> Slope <input checked="" type="checkbox"/> Upland <u> </u> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5