

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 NW 1/4 NW 1/4	Section number 33	Township number T 26	Range number S R 1E	E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 3747 North Topeka Wichita, Kansas			3. Owner of well: Evans Steel Building R.R. or street: 1030 South McComas City, state, zip code: Wichita, Kansas			
4. Locate with "X" in section below: <div style="text-align: center;"> </div> Sketch map:			6. Bore hole dia. 11 in. Completion date 10-17-78 Well depth 45 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Styrene Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. 5 in. to 45 ft. depth gage No. 200			
			10. Screen: Manufacturer's name Sunflower plastic Type styrene Dia. 5" Slot/gauge .06 Length 15' Set between 30 ft. and 45 ft. ft. and 45 ft. Gravel pack? yes Size range of material 1/4-1/8"			
(Use a second sheet if needed)			11. Static water level: 15 ft. below land surface Date 10-17-78 mo./day/yr.			
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
			13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____			
			14. Well head completion: 12 capped ____ Pitless adapter ____ inches above grade			
			15. Well grouted? yes 1-2 fine sand mix With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.			
			16. Nearest source of possible contamination: City Sewer ft. 80 Direction East Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No ____			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other			
			18. Elevation:			
			19. Remarks: Flat ground			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 12-2-78 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5