

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>Sedgwick</u>		<u>NE</u> 1/4 <u>NE</u> 1/4 <u>NW</u> 1/4	<u>34</u>	T <u>26</u> S	R <u>1</u> <u>EW</u>
Distance and direction from nearest town or city street address of well if located within city? <u>2100 E 37th N.</u> <span style="float:right"><u>MW 10</u></span>					
2 WATER WELL OWNER: <u>Unocal</u>					
RR#, St. Address, Box # : <u>2100 E. 37th Wichita Ks</u>					
City, State, ZIP Code : <u>2100 E. 37th Wichita Ks</u> Board of Agriculture, Division of Water Resources Application Number:					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>36</u> ft. ELEVATION:			
		Depth(s) Groundwater Encountered 1. <u>11.2</u> ft. 2. <u>36</u> ft. 3. <u>36</u> ft.			
		WELL'S STATIC WATER LEVEL <u>11.2</u> ft. below land surface measured on mo/day/yr			
		Pump test data: Well water was <u>8</u> ft. after <u>36</u> hours pumping <u>36</u> gpm			
		Est. Yield <u>8</u> gpm Well water was <u>36</u> ft. after <u>36</u> hours pumping <u>36</u> gpm			
Bore Hole Diameter <u>8</u> in. to <u>36</u> ft. and <u>36</u> in. to <u>36</u> ft.		WELL WATER TO BE USED AS:			
1 Domestic		3 Feedlot	6 Oil field water supply	9 Dewatering	12 Other (Specify below)
2 Irrigation		4 Industrial	7 Lawn and garden only	10 Monitoring well	
Was a chemical/bacteriological sample submitted to Department? Yes <u>No</u> If yes, mo/day/yr sample was submitted					
Water Well Disinfected? Yes <u>No</u>					
5 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued <u>Clamped</u>
2 PVC		4 ABS	6 Asbestos-Cement	9 Other (specify below)	Welded <u>Threaded</u>
Blank casing diameter <u>2</u> in. to <u>14.5</u> ft. Dia <u>14.5</u> in. to <u>34.5</u> ft. Dia <u>34.5</u> in. to <u>36</u> ft. Dia <u>36</u> in. to <u>36</u> ft.		7 Fiberglass			
Casing height above land surface <u>14.5</u> in., weight <u>34.5</u> lbs./ft. Wall thickness or gauge No. <u>36</u>					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel	5 Fiberglass	8 RMP (SR)	10 Asbestos-cement
2 Brass		4 Galvanized steel	6 Concrete tile	9 ABS	11 Other (specify)
SCREEN OR PERFORATION OPENINGS ARE:					
1 Continuous slot		3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
2 Louvered shutter		4 Key punched	6 Wire wrapped	9 Drilled holes	
SCREEN-PERFORATED INTERVALS: From <u>14.5</u> ft. to <u>34.5</u> ft. From <u>34.5</u> ft. to <u>36</u> ft.					
GRAVEL PACK INTERVALS: From <u>13.5</u> ft. to <u>36</u> ft. From <u>36</u> ft. to <u>36</u> ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other					
Grout Intervals: From <u>0</u> ft. to <u>13.5</u> ft. From <u>13.5</u> ft. to <u>36</u> ft. From <u>36</u> ft. to <u>36</u> ft.					
What is the nearest source of possible contamination:					
1 Septic tank		4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
2 Sewer lines		5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines		6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
Direction from well? <u>Within</u>		How many feet? <u>Within</u>			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>15</u>	<u>Silty clay</u>			
<u>15</u>	<u>TD</u>	<u>clay w/ silty sand</u>			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>12/14/92</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>10292</u> This Water Well Record was completed on (mo/day/yr) <u>12/21/92</u> under the business name of <u>Jayne</u> by (signature) <u>Omeller</u>					