

WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL: <b>Sedgwick</b>	FRACTION <b>SE 1/4 SE 1/4 NW 1/4</b>	SECTION NUMBER <b>34</b>	TOWNSHIP NUMBER <b>T 26 S</b>	RANGE NUMBER <b>R 2E E/W</b>
--	---	-----------------------------	----------------------------------	---------------------------------

Distance and direction from nearest town or city street address of well if located within city?  
**11421 E. Brookview Ct. Wichita, Kansas**

2 WATER WELL OWNER: RR#, ST. ADDRESS, BOX #: CITY, STATE:	<b>ROBL CONSTRUCTION 5842 W. 21st N. Wichita, Kansas</b>	Board of Agriculture, Division of Water Resource Application Number:
	ZIP CODE: <b>67205</b>	

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 	4 DEPTH OF COMPLETED WELL: <b>95</b> ft. ELEVATION:	
	Depth of groundwater Encountered: _____ ft.	ft.
	WELL'S STATIC WATER LEVEL <b>30</b> FT. BELOW LAND SURFACE MEASURED ON <b>7/30/19</b>	
	Pump test data: Well water was _____ ft. after _____ hours of pumping @ _____ gpm	ft. after _____ hours of pumping @ _____ gpm
Est. Yield: _____ gpm	Well water was _____ ft. after _____ hours of pumping @ _____ gpm	
Bore Hole Diameter <b>12</b> in. to <b>95</b> ft. and _____ in. to _____ ft.		
WELL WATER TO BE USED AS:		9. Dewatering 11. Injection well
1. Domestic 3. Feedlot 5. Public water supply <u>7. Lawn and garden only</u>		12. Other (Specify below)
2. Irrigation 4. Industrial 6. Oil field water supply 8. Air conditioning 10. Monitoring well		
Was a chemical/bacteriological sample submitted to Department? <b>YES</b> <u>NO</u> ; If yes, what mo/day/yr was sample submitted		Was Water Well Disinfected? <b>YES</b> <u>NO</u>

5 TYPE OF CASING USED:	1. Steel	3. RPM (SR)	5. Wrought Iron	7. Fiberglass	9. Other (Specify below)	CASING JOINTS: <u>Glued</u> Threaded
	<u>2. PVC</u>	4. ABS	6. Asbestos-Cement	8. Concrete tile	SDR-26	Welded Clamped
Blank casing diameter	<b>5</b> in.	to <b>30</b> ft.,	Dia.	in.	to	ft., Dia. in. to ft.
Casing height above land surface:	<b>12</b> in.,	Weight: <b>2.35</b> lbs. / ft.	Wall thickness or gauge No. <b>.214</b>			
TYPE OF SCREEN OR PERFORATION MATERIAL:	1. Steel	3. Stainless Steel	5. Fiberglass	<u>7. PVC</u>	9. ABS	11. Other (specify)
	2. Brass	4. Galvanized	6. Concrete Tile	8. RMP (SR)	10. Asbestos-Cement	12. None used (open hole)
SCREEN OR PERFORATION OPENINGS ARE:	1. Continuous slot	3. Mill slot	5. Gauzed wrapped	7. Torch cut	9. Drilled holes	11. None (open hole)
	2. Louvered shutter	4. Key punched	6. Wire wrapped	<u>8. Saw cut</u>	10. Other (specify)	
SCREEN - PERFORATION INTERVAL	From <b>30</b> ft.	to <b>95</b> ft.,	From _____ ft.	to _____ ft.	From _____ ft.	to _____ ft.
GRAVEL PACK INTERVALS:	From <b>24</b> ft.	to <b>95</b> ft.,	From _____ ft.	to _____ ft.	From _____ ft.	to _____ ft.

6 GROUT MATERIALS:	1. Neat cement	2. Cement Grout	3. Bentonite	Other <b>bentonite hole plug</b>
Grout Intervals:	From _____ ft.	to _____ ft.,	From _____ ft.	to _____ ft.
What is the nearest source of possible contamination:	<b>3. Watertight sewer line</b>	6. Seepage pit	9. Feed yard	12. Fertilizer storage
	1. Septic tank	4. Lateral lines	7. Pit privy	10. Livestock pens
	2. Sewer lines	5. Cess Pool	8. Sewage lagoon	11. Fuel storage
				13. Insecticide storage
				14. Abandon water well
				15. Oil well/Gas well
				16. Other (specify below)

Direction from well? **Southwest** How many feet? **80 ft. plus**

From	To	LITHOLOGIC LOG	From	To	LITHOLOGIC LOG
0	3	topsoil			
3	11	clay			
11	52	brown shale			
52	95	grey shale			

7 Contractor's or Landowner's Certification: This water well was 1. <u>constructed</u> 2. reconstructed or 3. plugged under my jurisdiction and was completed on (mo/day/year) <b>7/30/19</b> and this record is true to the best of my knowledge and belief.	
Kansas Water Well Contractor's License No. 236 under the business name of <b>Harp Well and Pump Service</b>	This water well record was completed on (mo/day/year) <b>8/1/19</b> by (signature) <b>Todd S. Harp</b>