


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Sedgwick</u> Fraction <u>1/4 NE 1/4 SE 1/4</u> Section number <u>9</u> Township number <u>T 26 S</u> Range number <u>R 2 E</u>	
2. Distance and direction from nearest town or city: <u>6427 N. Greenwood</u> 3. Owner of well: <u>Don Langford</u> Street address of well location if in city: <u>Wichita, Kans.</u> R. or street: <u>4135 Regents Lane</u> City, state, zip code: <u>Wichita, Kans.</u>	
4. Locate with "X" in section below: Sketch map: 	
5. Type and color of material	
6. Bore hole dia. <u>5 1/2</u> in. Completion date <u>6-21-76</u> Well depth <u>55</u> ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <u>stipene</u> (height: above or below surface) <u>12</u> in. Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> RMP <input checked="" type="checkbox"/> PVC Weight <u>12</u> lbs./ft. Dia. <u>5</u> in. to <u>55</u> ft. depth Wall Thickness: inches or Dia. <u>200</u> in. to <u>55</u> ft. depth gage No. <u>200</u>	
10. Screen: Manufacturer's name <u>Surflam Plastic</u> Type <u>stipene</u> Dia. <u>5</u> in. Slot/gauze <u>1.06</u> Length <u>30</u> ft. Set between <u>25</u> ft. and <u>55</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8</u>	
11. Static water level: <u>18</u> ft. below land surface Date <u>6-21-76</u>	
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
13. Water sample submitted: _____ mo./day/yr. _____ Yes _____ No Date _____	
14. Well head completion: <u>12</u> capped _____ Pitless adapter _____ Inches above grade	
15. Well grouted? <u>yes</u> With: _____ Neat cement _____ Bentonite _____ Concrete Depth: From <u>40</u> ft. to <u>14</u> ft.	
16. Nearest source of possible contamination: <u>none</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ HP _____ Volts _____ Model number _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <u>Septic Tank not installed when well was drilled.</u> <u>No apparent source for contamination.</u>
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Harold Well Pump</u> 236 Business name License No. <u>Wichita Kansas</u> Address <u>M. Arnold</u> Date <u>8-9-76</u> Signed _____ Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Pump not installed at this time.