


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Sedgwick</b>	Fraction <b>1/4 SW 1/4 SE 1/4</b>	Section number <b>9</b>	Township number <b>T 26 S R 2 E</b>	Range number <b>E/W</b>
2. Distance and direction from nearest town or city: Street address of well location if in city: <b>10700 East 87th South Wichita, Kansas</b>				3. Owner of well: Terry Ploeckelmann R.R. or street: 5020 Conuerys City, state, zip code: Derby, Kansas		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. <u>1</u> in. Completion date <u>6-30-77</u> Well depth <u>57</u> ft.		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lown <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>styrene</u> <input checked="" type="checkbox"/> Above or <input checked="" type="checkbox"/> Below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>12</u> lbs./ft. Dia. <u>5</u> in. to <u>57</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>57</u> ft. depth Gauge No. <u>200</u>		
				10. Screen: Manufacturer's name <u>Sunflower Plastic</u> Type <u>styrene</u> Dia. <u>5"</u> Slot/gauge <u>.06</u> Length <u>20'</u> Set between <u>31</u> ft. and <u>51</u> ft. <u>ft.</u> and <u>ft.</u> Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>		
				11. Static water level: <u>35</u> ft. below land surface Date <u>6-30-77</u> mo./day/yr.		
				12. Pumping level below land surfaces: <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>g.p.m.</u>		
				13. Water sample submitted: <u>mo./day/yr.</u> <u>Yes</u> <u>No</u> Date <u>6-30-77</u>		
				14. Well head completion: <u>capped</u> <u>Pitless adapter</u> <u>12</u> inches above grade		
				15. Well grouted? <u>yes</u> <u>1-2 fine sand mix</u> With: <u>Neat cement</u> <u>Bentonite</u> <input checked="" type="checkbox"/> <u>Concrete</u> Depth: From <u>40"</u> ft. to <u>14</u> ft.		
				16. Nearest source of possible contamination: <u>NONE</u> ft. <u>Direction</u> <u>Type</u> Well disinfected upon completion? <input checked="" type="checkbox"/> <u>Yes</u> <u>No</u>		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>HP</u> HP <u>Volts</u> Model number <u>Length of drop pipe</u> ft. capacity <u>g.p.m.</u> Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Harp Well &amp; Pump 236</b> Business name <u>Wichita, Kansas</u> License No. <u>236</u> Address <u>M. Arnold</u> Signed <u>M. Arnold</u> Date <u>6-2-77</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Septic system not installed at this time.  No apparent source for contamination.				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5