

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEDGWICK	Fraction 1/4 SE 1/4 SE 1/4	Section number 11	Township number T 26 S	Range number R 2E E/W
2. Distance and direction from nearest town or city: 14300 E. 61st N. Wichita, Kansas			3. Owner of well: Mike Huff Construction R.R. or street: 929 So. Rock Rd. City, state, zip code: Wichita, Kansas			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 11 in. Completion date 6-23-78 Well depth 71 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stack <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material styrene Height: Above or below 11 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 71 ft. depth Wall Thickness: inches or Dia. 5 in. to 71 ft. depth gage No. 200	
					10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/size .06 Length 50' Set between 21 ft. and 71 ft. Gravel pack? yes Size range of material 1/4-1/8"	
5. Type and color of material		From		To		11. Static water level: 20 ft. below land surface Date 6-23-78
Topsoil		0		3		12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
Brown Shale		3		40		13. Water sample submitted: ____ Yes ____ No Date ____
Gray Shale		40		65		14. Well head completion: capped ____ Pitless adapter 12 Inches above grade
Limestone		65		71		15. Well grouted? yes 1-2 Fine Sand Mix With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40' ft. to 14 ft.
						16. Nearest source of possible contamination: septic ft. 100 Direction East Type tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No
						17. Pump: ____ Not installed Manufacturer's name Sta-Rite Model number 20P4C02 HP 1/2 Volts 230 Length of drop pipe 65 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 6-30-78 Authorized representative
18. Elevation:		19. Remarks: Flat Ground				
Topography: ____ Hill ____ Slope ____ Upland ____ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5