


1 LOCATION OF WATER WELL:		FRACTION			Water Well Record Form WWC-3 KSA 62-1212		Section Number	Township Number	Range Number	
Butler		NE 1/4	NE 1/4	SE 1/4	25		T 26 S	R 3 E	E/W	
Distance and direction from nearest town or city street address of well if located within city?										
1/2 S. of 45th St. N., West side of Indianola					Benton, Kansas					
WATER WELL OWNER:		MOSES, Darrel			Board of Agriculture, Division of Water Resource					
RR#, ST. ADDRESS, BOX #:		13025 S.W. 43rd			Application Number:					
CITY, STATE, ZIP CODE:		Benton, Kansas								
LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:					4 DEPTH OF COMPLETED WELL 140 ft. ELEVATION:					
		Depth(s) groundwater Encountered 1 ft. 2 ft. 3 ft.								
		WELL'S STATIC WATER LEVEL 70 FT. BELOW LAND SURFACE MEASURED ON mo/day/yr 02/22/1999								
		Pump test data: Well water was ft. after hours pumping gpm								
		Est. Yield gpm: Well water was ft. after hours pumping gpm								
		Bore Hole Diameter 12 in. to 140 ft. and in. to ft.								
		WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well								
		1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)								
		2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well								
		Was a chemical/bacteriological sample submitted to Department? Yes No <input checked="" type="checkbox"/> ; If yes, mo/day/yr sample was submitted					Water Well Disinfected? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			
5	TYPE OF CASING USED:				5 Wrought iron 8 Concrete tile CASING JOINTS: Glued <input checked="" type="checkbox"/> Clamped					
	1 Steel	3 RMP (SR)	6 Asbestos-Cement		9 Other (Specify below)		Welded			
	2 PVC	4 ABS	7 Fiberglass		SDR - 26		Threaded			
	Blank casing Diameter 5 in. to 20 ft., Dia		in. to weight 2.35 lbs. / ft.		ft., Dia		in. to ft.			
	Casing height above land surface 12 in.,				7 PVC		Wall thickness or gauge No. 10 Asbestos-cement		.214	
	TYPE OF SCREEN OR PERFORATION MATERIAL:				5 Fiberglass 8 RMP (SR)		11 other (specify)			
	1 Steel	3 Stainless Steel	6 Concrete tile		9 ABS		12 None used (open hole)			
	2 Brass	4 Galvanized steel	7 Torch cut		8 Saw cut		11 None (open hole)			
	SCREEN OR PERFORATION OPENING ARE:				6 Wire wrapped		9 Drilled holes			
	1 Continous slot	3 Mill slot	7 Key punched		10 Other (specify)					
	2 Louvered shutter	4 Key punched								
	SCREEN-PERFORATION INTERVALS:				from 20 ft. to 140 ft., From		ft. to			ft.
					from ft. to		ft. to			ft.
	GRAVEL PACK INTERVALS:				from 30 ft. to 140 ft., From		ft. to			ft.
					from ft. to		ft. to			ft.
6	GROUT MATERIAL:		1 Neat cement	2 Cement grout	3 Bentonite	4 Other	bentonite hole plug			
	Grout Intervals: From 4 ft. to 26 ft. From				ft. to	ft. From	26 ft. to 28 ft.			
	What is the nearest source of possible contamination:						10 Livestock pens	14 Abandon water well		
	1 Septic tank	4 Lateral lines	7 Pit privy				11 Fuel storage	15 Oil well/Gas well		
	2 Sewer lines	5 Cess pool	8 Sewage lagoon				12 Fertilizer storage	16 Other (specify below)		
	3 Watertight sewer lines	6 Seepage pit	9 Feedyard				13 Insecticide storage			
	Direction from well? South				How many feet? 200					
	FROM	TO	LITHOLOGIC LOG			FROM	TO	PLUGGING INTERVALS		
0	3	topsoil								
3	12	clay								
12	60	brown shale								
60	140	gray shale								
7	CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 02/22/1999 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236. This Water Well Record was completed on (mo/day/yr) 02/24/99. Under the business name of Harp Well & Pump Service, Inc. by (signature)									