

1. Location of well:	County: Benton	Fraction: SE 1/4 SE 1/4 SE 1/4	Section number: 5	Township number: T 26 S R 3	Range number: 0
2. Distance and direction from nearest town or city:	1/2 mi. N. 170.		3. Owner of well:	LELAND W. WIT	
Street address of well location if in city:	of Benton corner		R.R. or street:	Rt 1	
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 8 1/4 in. Completion date 8-4-78 Well depth 46 ft.		
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
5. Type and color of material	From: 0 2	To: 2 16	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
TOP SOIL	0 2	16 24	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded Surface 0 18 in. RMP 8 1/2 Weight 1258 lbs./ft. Dia. 5 in. to 36 ft. depth! Wall Thickness: inches or Dia. 5 in. to 10 ft. depth! gage No. 1258		
Red CLAY	2 16	24 46	10. Screen: Manufacturer's name M. P. I.		
Lime WHite	16 24	46	Type PVC Dia. 5 Sieve gauze 25/1000 Length 10 Set between 36 ft. and 46 ft. ft. and 46 ft. Gravel pack? yes Size range of material 5/8		
SHALE GRAY	24 46		11. Static water level: 18 ft. below land surface Date 8-4-78		
			12. Pumping level below land surfaces: 18 ft. after 0 hrs. pumping 0 g.p.m. 18 ft. after 0 hrs. pumping 0 g.p.m. Estimated maximum yield 30 g.p.m.		
			13. Water sample submitted: 0 mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 8-4-78		
			14. Well head completion: S A P <input type="checkbox"/> Pitless adapter 18 inches above grade		
			15. Well grouted? XCS With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: Feedlot ft. 90 Direction 80 Type Feedlot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name PREWIT CONST. CO. 353 Model number Box 764 HP 0 Volts 0 Length of drop pipe 0 ft. capacity 0 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PREWIT CONST. CO. 353 Business name Box 764 License No. 0478 Address Box 764 Date 8-4-78 Signed Leeland Wit Authorized representative 0478		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					