

County Bath		Fraction SE 1/4 NW 1/4 NW 1/4		Section number 21		Township number T 26 S R 3 E	
1. Location of well: 3/4 So. of Benton				3. Owner of well: Keith Joy			
Street address of well location if in city:				City, state, zip code: Benton 67217			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 1/2 in. Completion date 9-25-78 Well depth 46 ft.			
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top soil		0		3		9. Casing: Material P.V.C. Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input checked="" type="checkbox"/> 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> GL Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 36 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258	
Red Clay		3		16		10. Screen: Manufacturer's name M.P.I. Type P.V.C. Dia. 5 Slot/gauze 25/100 Length 16 Set between 36 ft. and 46 ft. ft. and <input type="checkbox"/> ft.	
Limestone (White)		16		38		Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/9	
Shale (Gray)		38		46		11. Static water level: <input type="checkbox"/> mo./day/yr. 18 ft. below land surface Date 9-25-78	
						12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 20 g.p.m.	
						13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 9-25-78	
						14. Well head completion: CAP <input checked="" type="checkbox"/> Pitless adapter 16 inches above grade	
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
						16. Nearest source of possible contamination: ft. 20 Direction N.W. Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		owner will install a 4x4x4 concrete slab Keith Joy		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Prewitt Const Co 353 Business name _____ License No. _____ Address Box 944 Auto C/Pruit 9-25-78 Signed _____ Authorized representative Date			