


1. Location of well:	County BUTLER	Fraction SW 1/4 SE 1/4 NE 1/4	Section number 25	Township number T 26	Range number S R 3E E/W
2. Distance and direction from nearest town or city:	#3 Briar Cliff Dr.		3. Owner of well:	Lynn Copeland Homes Inc.	
Street address of well location if in city:	Briar Cliff Estates Andover, Kansas		P.R. or street: City, state, zip code:	6827 E. Harry Wichita, Kansas	
4. Locate with "X" in section below:	 $2\frac{1}{2} N, 4 E$ of Andover.		Sketch map:	6. Bore hole dia. 11 in. Completion date 5-16-78 Well depth 125 ft.	
5. Type and color of material	From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Topsoil	0	3	9. Casing: Material Styrene Height: Above or below Threaded <input type="checkbox"/> Welded gl Surface 12 in. RMP X PVC Weight lbs./ft. Dia. 5 in. to 125 ft. depth Wall Thickness: inches or Dia. 5 in. to 125 ft. depth gage No. 200	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot .06 Length 60' Set between 65 ft. and 125 ft. ft. and 125 ft. Gravel pack? yes Size range of material 1-1/8"	
Brown Clay	3	6	11. Static water level: 60 ft. below land surface Date 5-16-78	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
Light Tan Shale	6	25	13. Water sample submitted: mo./day/yr. Yes No Date 	14. Well head completion: capped <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Light Blue Shale	25	50	15. Well grouted? yes 1-2 Fine Sand Mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.	16. Nearest source of possible contamination: ft. Direction Type NONE Well disinfected upon completion? X Yes No 	
Blue Shale	85	125	17. Pump: X Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	
(Use a second sheet if needed)			19. Remarks: Septic system not installed at this time. No apparent source for contamination.	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 5-14-78 Authorized representative 	