



1. Location of well:	County	Fraction	Section number	Township number	Range number	
Butler	NE $\frac{1}{4}$ NW $\frac{1}{4}$ NW $\frac{1}{4}$	25	T 26	S	R 3	
2. Distance and direction from nearest town or city: BENTON	WYSO 3E of	3. Owner of well: Herb Bruce				
Street address of well location if in city: WICHITA KS	16405 E. 45th, N.	R.R. or street: 7701 E Kellogg				
4. Locate with "X" in section below:	Sketch map:	6. Bore hole dia. 8.5 in. Completion date 8-24-77 Well depth 47 ft.				
		7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
5. Type and color of material	From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Fill Dirt	0	1	9. Casing: Material PITS Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight lbs./ft. Dia. 5 in. to 97 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1200			
Top Soil	1	2	10. Screen: Manufacturer's name SUNFlower PITS PIPE INC Type RMP Dia. 5"			
Brown clay	2	10	Slot/gauze 1/16 Length 10' Set between 87 ft. and 97 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-3/4			
Lime Stone yellow	10	28	11. Static water level: mo./day/yr. 66 ft. below land surface Date 8/24/78			
Limestone yellow with clay	28	35	12. Pumping level below land surfaces: NA ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.			
Shale gray	35	44	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date			
Clay green	44	49	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade			
Clay Lavender	49	52	15. Well grouted? YES With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 13 ft. to 33 ft.			
Clay light gray green	52	59	16. Nearest source of possible contamination: NA ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Limestone yellow with clay	59	65	17. Pump: Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Shale gray green	65	83	18. Elevation: 19. Remarks: OWNER WILL INSTALL CONCRETE SLAB			
Limestone yellow (water)	83	95	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Braddy Water Wells 363 Business name <input type="checkbox"/> License No. Address P.O. Box 2177 Douglass KS Signed <input type="checkbox"/> Date 8-21-78 Authorized representative			
Shale blue gray	95	97				
(Use a second sheet if needed)						
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						