


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY:

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County Butler	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 25	Township number T 26 S	Range number R 3 E
2. Distance and direction from nearest town or city: Corner of Santa Fe Lake Road & Street address of well location if in city: 37th St. No. on the		3. Owner of well: John Harding R.R. or street: R. # 3 City, state, zip code: Augusta, Kansas		
4. Locate with "X" in section below: N  E S 1 Mile		6. Bore hole dia. 11 in. Completion date Well depth 110 ft. 10-18-76		
		7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
		9. Casing: Material styrene Height: Above or Threaded <input type="checkbox"/> Welded 81 Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight lbs./ft. Dia. 5 in. to 110 ft. depth Wall Thickness inches or Dia. in. to ft. depth gage No. 200		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Sunflower Plastic
Topsoil		0	3	Type styrene Dia. 5" Slot/size .06 Length 40' Set between 70 ft. and 110 ft. Gravel pack? yes Size range of material 1-1/8"
Clay (Grey)		3	15	11. Static water level: 60 ft. below land surface Date 10-18-76
Brown Sandstone		15	40	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
Blue Shale		40	80	13. Water sample submitted: mo./day/yr. Yes No Date
Red Shale		80	85	14. Well head completion: capped Pitless adapter 12 inches above grade
Blue Shale		85	110	15. Well grouted? yes With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40 ft. to 14 ft.
				16. Nearest source of possible contamination: NONE ft. direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes No
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
				18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley
				19. Remarks: Septic Tank was not installed when the well was drilled. No apparent source for contamination.
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Address Wichita, Kansas License No. Signed <i>M. Arnold</i> Date 10-30-76 Authorized representative