USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Butler	NW 1/4 NW 1/4 NE 1/4	4	T 26 S	R 4 E

2. Distance and direction from nearest town or city: ½ mil EAST OF TOWANDA KANSAS on 254 Hy Then 2 mil N. + ½ mil
Street address of well location if in city: WEST on SO side OF ROAD

3. Owner of well: BERT PERSON'S
R.R. or street: 328 So. Bluff
City, state, zip code: Wichita Ks.

4. Locate with "X" in section below:



Sketch map:



6. Bore hole dia. 10 in. Completion date 6-20-80
Well depth 150 ft.

7. ✓ Cable tool ___ Rotary ___ Driven ___ Dug
___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary

8. Use: ✓ Domestic ___ Public supply ___ Industry
___ Irrigation ✓ Air conditioning ___ Stock
___ Lawn ___ Oil field water ___ Other

9. Casing: Material PLIS Height: Above or below
Threaded ___ Welded ___ Surface 16 in.
RMP ___ PVC ___ Weight ___ lbs./ft.
Dia 5 in. to 150 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. ___

5. Type and color of material	From	To
TOPSOIL	0	12
Brown CLAY	12	20
SHALE Brownish	20	26
Lime & gravel — V to C water	26	30
SHALE gray	30	43
SHALE Blueish	43	76
Lime V Gravel	76	96
SHALE Gray	96	148
SHALE Brown	148	150

(Use a second sheet if needed)

10. Screen: Manufacturer's name Jess + Lowell
Type ___ Dia. 5"
Slot/gauze 1/16 Length 20ft
Set between 130 ft. and 150 ft.
___ ft. and ___ ft.
Gravel pack? ✓ Size range of material ⅛ to ¼

11. Static water level: mo./day/yr.
12 ft. below land surface Date 6-19-80

12. Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
___ Yes ✓ No Date ___

14. Well head completion:
___ Pitless adapter ___ Inches above grade

15. Well grouted? yes
With: ___ Neat cement ___ Bentonite ✓ Concrete
Depth: From 8 ft. to 18 ft.

16. Nearest source of possible contamination:
ft. 60 Direction EAST Type Creek
Well disinfected upon completion? ✓ Yes ___ No

17. Pump: ✓ Not installed
Manufacturer's name ___
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.p.m.
Type:
___ Submersible ___ Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

18. Elevation:

Topography:
___ Hill
___ Slope
___ Upland
___ Valley

19. Remarks: well WAS Drilled IN BASEMENT

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
B + J well Drl 335
Business name License No.
Address RR 1
Signed Bart Hogeboom Date 6-23-80
Authorized representative