


1. Location of well:	County <i>Butler</i>	Fraction <i>NW 1/4 SE 1/4 SW 1/4</i>	Section number <i>25</i>	Township number <i>T 26 S 10 R 4</i>	Range number <i>EW</i>
2. Distance and direction from nearest town or city: Street address of well location if in city:	<i>4N. 1/2 E 1/4 N of Augusta Kans</i>		3. Owner of well: R.R. or street: City, state, zip code:	<i>Larry Schneiderwind Route 1 Augusta Kans 67010</i>	
4. Locate with "X" in section below:	Sketch map:  <i>hot pasture but grassland.</i>			6. Bore hole dia. <u>9</u> in. Completion date <u>10-17-75</u> Well depth <u>120</u> ft.	
5. Type and color of material	From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Red Clay	0	5	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
yellow lime	5	30	9. Casing: Material <u>PLTS</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>gauge</u> Surface <u>78</u> in. RMP <u>X</u> PVC Weight <u>100</u> lbs./ft. Dia. <u>6</u> in. to <u>100</u> ft. depth Wall Thickness: inches or Dia. <u>6</u> in. to <u>100</u> ft. depth gage No. <u>175</u>		
grey lime	30	110	10. Screen: Manufacturer's name <u>Sunflower</u> <u>Plastics. pipe Inc.</u> Type <u>RMP</u> Dia. <u>62m</u> Slot/gauze <u>1/8</u> Length <u>20 ft</u> Set between <u>108</u> ft. and <u>120</u> ft. ft. and <u>120</u> ft. Gravel pack? <u>no</u> Size range of material _____		
Water	110		11. Static water level: <u>35</u> ft. below land surface Date <u>10-17-75</u>		
grey lime	110	120	12. Pumping level below land surfaces: ft. after _____ hrs. pumping _____ g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>8</u> g.p.m.		
			13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
			14. Well head completion: Pitless adapter <u>18</u> Inches above grade		
			15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>12</u> ft.		
			16. Nearest source of possible contamination: ft. <u>500</u> Direction <u>north</u> Type <u>stock pond</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <u>not</u> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	(Use a second sheet if needed)		19. Remarks: <i>Concrete slab to be installed by owner</i> <i>Larry Schneiderwind</i>		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Murrayville well Drilling</i> Business name _____ License No. _____ Address <i>Route 3, Augusta 67010</i> Signed <i>Murrayville Kans</i> Date <i>10-17-75</i> Authorized representative _____		