

1. Location of well:	County Barton	Fraction NE 1/4 NE 1/4 1/4	Section number 30	Township number T 26	Range number 4
2. Distance and direction from nearest town or city:	4 1/2 5N		3. Owner of well:	Bob Barch	
Street address of well location if in city:	Augusta		R.R. or street:	R 27 Towanda	
4. Locate with "X" in section below:			Sketch map:		
5. Type and color of material	From	To	6. Bore hole dia. 3 in. Completion date 7/31/18 Well depth 70 ft.		
Soil Black	0	4	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Rock yellow	4	15	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Lime & Shale	15	40	9. Casing: Material PLT Height: Above or below Threaded <input type="checkbox"/> Welded SL Surface 15 in. RMP 100 PVC Weight 100 lbs./ft. Dia. 6 in. to 40 ft. depth Wall Thickness, inches or Dia. 6 in. to 40 ft. depth Gage No. 175		
Lime	40	60	10. Screen: Manufacturer's name Screen Flow Type 100 Dia. 6 Slot/gauze 150 Length 20 Set between 50 ft. and 70 ft. ft. and ft. Gravel pack? NO Size range of material		
Shale	60	90	11. Static water level: 50 ft. below land surface Date 7/30/18		
			12. Pumping level below land surfaces: 50 ft. after 1 hrs. pumping 50 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50 g.p.m.		
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 15 inches above grade <input checked="" type="checkbox"/> Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			15. Nearest source of possible contamination: ft. 200 Direction NE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			16. Pump: Not installed Manufacturer's name Grands Model number 1 HP 1 Volts 230 Length of drop pipe 55 ft. capacity 75 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	(Use a second sheet if needed)		17. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name Walter Well Drill 25YA Address R 2 Box 30 Augusta Signed Walter Well Drill 25YA Date 7/31/18 Authorized representative Walter Well Drill 25YA		
Topography:	<input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				
19. Remarks:	Owner to install concrete slab around well				