

1. Location of well:	County <b>BUTLER</b>	Fraction $N \frac{1}{2} 1/4 N W 1/4 SW 1/4$	Section number <b>34</b>	Township number <b>T 26</b>	Range number <b>S R 5 E</b>	
2. Distance and direction from nearest town or city:	4 1/2 miles S. TH OF E 1/4 DODGE, KANSAS CITY		3. Owner of well: R.R. or street: City, state, zip code:	<b>GREID BUDICK R. T. 1 DODGE CITY, KANSAS</b>		
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. <b>10</b> in. Completion date <b>9-1-78</b> Well depth <b>120</b> ft.			
	N	E	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
	W	S	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material	From	To	9. Casing: Material _____ Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>36</b> in. RMP _____ PVC <input checked="" type="checkbox"/> Weight <b>3040</b> lbs./ft. Dia. <b>5</b> in. to <b>120</b> ft. depth! Wall thickness: inches or Dia. <b>5</b> in. to <b>120</b> ft. depth gage No. <b>.258</b>			
	0	2	10. Screen: Manufacturer's name <b>ASTM</b> Type <b>80 #40</b> Dia. <b>5 in</b> Slot/gauge <b>.025</b> Length <b>10</b> Set between <b>110</b> ft. and <b>120</b> ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>.804</b>			
	2	6	11. Static water level: <b>22</b> ft. below land surface Date <b>9-8-78</b>			
	6	23	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield <b>1900</b> g.p.m.			
	23	48	13. Water sample submitted: <b>Yes</b> <input checked="" type="checkbox"/> <b>No</b> <input type="checkbox"/> Date _____			
	48	58	14. Well head completion: <b>Pitless adapter</b> <b>36</b> inches above grade			
	58	68	15. Well grouted? <b>Yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.			
	68	71	16. Nearest source of possible contamination: ft. <b>200</b> Direction <b>North</b> Type <b>Septic tank</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
	71	89	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
	89	96	18. Elevation: <b>on Reguard Rd # 16</b>	19. Remarks: <b>on Reguard Rd # 16</b> <b>there is a new unsewed Septic</b> <b>Tank 150 ft 200 ft N west of</b> <b>well</b>		
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>B + S Drilling 335</b> Business name <b>B + S Drilling</b> License No. <b>123456789</b> Address <b>Bart Hargrave</b> Signed <b>Bart Hargrave</b> Date <b>9-10-78</b> Authorized representative			