

LOCATION OF WATER WELL:
County: Sedgwick
Fraction: SW 1/4 SE 1/4 NE 1/4
Section Number: 21
Township Number: T 27 S
Range Number: R 1 E
Distance and direction from nearest town or city street address of well if located within city?
125 N. Mathewson, Wichita

MW-3

WATER WELL OWNER: Robinson - Leslie
St. Address, Box #: 125 N. Mathewson
State, ZIP Code: Wichita, KS 67211
Board of Agriculture, Division of Water Resources
Application Number:

LOCATE WELL'S LOCATION WITHIN SECTION BOX:

DEPTH OF COMPLETED WELL: 23 ft. ELEVATION:
Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft.
WELL'S STATIC WATER LEVEL ft. below land surface measured on mo/day/yr
Pump test data: Well water was ft. after hours pumping gpm
Est. Yield gpm: Well water was ft. after hours pumping gpm
Bore Hole Diameter 8 in. to 23 ft. and in. to ft.
WELL WATER TO BE USED AS:
5 Public water supply 8 Air conditioning 11 Injection well
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well
Was a chemical/bacteriological sample submitted to Department? Yes No; If yes, mo/day/yr sample was submitted
Water Well Disinfected? Yes No

TYPE OF BLANK CASING USED:
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
7 Fiberglass Pulled Threaded
Casing diameter 2 in. to ft. Dia. in. to ft. Dia. in. to ft.
Casing height above land surface in. weight lbs./ft. Wall thickness or gauge No.
TYPE OF SCREEN OR PERFORATION MATERIAL:
1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement
2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify) Pulled
9 ABS 12 None used (open hole)
SCREEN OR PERFORATION OPENINGS ARE:
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
7 Torch cut 10 Other (specify) Pulled
SCREEN-PERFORATED INTERVALS: From 13 ft. to 23 ft. From ft. to ft.
From ft. to ft. From ft. to ft.
GRAVEL PACK INTERVALS: From ft. to ft. From ft. to ft.
From ft. to ft. From ft. to ft.
BROUT MATERIAL:
1 Neat cement 2 Cement grout 3 Bentonite 4 Other
Cut intervals: From 23 ft. to 2 ft. From 2 ft. to 0 ft. From ft. to ft.
What is the nearest source of possible contamination:
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well
2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)
Distance from well? West How many feet? 40
FROM TO LITHOLOGIC LOG FROM TO PLUGGING INTERVALS
0 2 CONCRETE
2 23 BENTONITE
RECEIVED
DEC 13 2000
BUREAU OF WATER
1410

CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) Nov 10, 2000 and this record is true to the best of my knowledge and belief. Kansas
Water Well Contractor's License No. 524 This Water Well Record was completed on (mo/day/yr) Nov 10, 2000
For the business name of Alfred Laboratories by (signature) [Signature]
INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-6545. Send one to WATER WELL OWNER and retain one for your records.