


WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL: Sedgwick		FRACTION SE 1/4 SE 1/4		SECTION NUMBER 17	TOWNSHIP NUMBER T 27 S		RANGE NUMBER R 1E E/W	
Distance and direction from nearest town or city street address of well if located within city? 633 N. Broadway Wichita, Kansas								
2 WATER WELL OWNER: KOONTZ, J.R. FLOWERS		Board of Agriculture, Division of Water Resource						
RR#,ST. ADDRESS,BOX #: 633 N. Broadway		Application Number:						
CITY, STATE: Wichita, Kansas		ZIP CODE:						
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 		4 DEPTH OF COMPLETED WELL: 40 ft. ELEVATION:						
1 Mile N NW NE SW SE S		Depth of groundwater Encountered: ft.						
		WELL'S STATIC WATER LEVEL 15 FT. BELOW LAND SURFACE MEASURED ON 3/22/03						
		Pump test data: Well water was ft. after hours of pumping @ gpm						
		Est. Yield: gpm Well water was ft. after hours of pumping @ gpm						
		Bore Hole Diameter 12 in. to 40 ft. and in. to ft.						
WELL WATER TO BE USED AS:		9. Dewatering 11. Injection well						
1. Domestic 3. Feedlot 5. Public water supply 7. Lawn and garden only 12. Other (Specify below)								
2. Irrigation 4. Industrial 6. Oil field water supply 8. Air conditioning 10. Monitoring well								
Was a chemical/bacteriological sample submitted to Department? YES NO		If yes, what mo/day/yr was sample submitted						
Was Water Well Disinfected? YES NO								
5 TYPE OF CASING USED:		CASING JOINTS: Glued Threaded						
1. Steel 3. RPM (SR) 5. Wrought Iron 7. Fiberglass 9. Other (Specify below)		Welded Clamped						
2. PVC 4. ABS 6. Asbestos-Cement 8. Concrete tile SDR-26								
Blank casing diameter 5 in. to 22 ft., Dia. in. to ft., Dia. in. to ft.								
Casing height above land surface: 12 in., Weight: 2.35 lbs. / ft. Wall thickness or gauge No. .214								
TYPE OF SCREEN OR PERFORATION MATERIAL:		12. None used (open hole)						
1. Steel 3. Stainless Steel 5. Fiberglass 7. PVC 9. ABS 11. Other (specify)								
2. Brass 4. Galvanized 6. Concrete Tile 8. RMP (SR) 10. Asbestos-Cement 12. None used (open hole)								
SCREEN OR PERFORATION OPENINGS ARE:		11. None (open hole)						
1. Continuous slot 3. Mill slot 5. Gauzed wrapped 7. Torch cut 9. Drilled holes								
2. Louvered shutter 4. Key punched 6. Wire wrapped 8. Saw cut 10. Other (specify)								
SCREEN - PERFORATION INTERVAL From 22 ft. to 40 ft., From ft. to ft., From ft. to ft.								
GRAVEL PACK INTERVALS: From 22 ft. to 40 ft., From ft. to ft., From ft. to ft.								
6 GROUT MATERIALS:		Other bentonite hole plug						
1. Neat cement 2. Cement Grout 3. Bentonite								
Grout Intervals: From 4 ft. to 24 ft., From ft. to ft., From ft. to ft.								
What is the nearest source of possible contamination:		16. Other (specify below)						
1. Septic tank 4. Lateral lines 7. Pit privy 10. Livestock pens 13. Insecticide storage 15. Oil well/Gas well								
2. Sewer lines 5. Cess Pool 8. Sewage lagoon 11. Fuel storage 14. Abandon water well								
3. Watertight sewer line 6. Seepage pit 9. Feed yard 12. Fertilizer storage								
Direction from well? West		How many feet? 75						
From To LITHOLOGIC LOG		From To LITHOLOGIC LOG						
0	4	topsoil						
4	15	clay						
15	37	medium sand						
37	40	shale						
7 Contractor's or Landowner's Certification: This water well was 1. constructed 2. reconstructed or 3. plugged under my jurisdiction and was completed on (mo/day/year) 3-22-2003 and this record is true to the best of my knowledge and belief.								
Kansas Water Well Contractor's License No. 236 This water well record was completed on (mo/day/year) 3-25-2003								
under the business name of Harp Well & Pump Service Inc. by (signature) <i>Todd S. Harp</i>								