

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction SE 1/4 SE 1/4 NW/4	Section number 29	Township number T 27 S	Range number R 1 E
2. Distance and direction from nearest town or city: Street address of well location if in city: 1019 South McLean Blvd.				3. Owner of well: Walcher Metal Company R.R. or street: McLean Blvd. City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile Well No. 1 (TH 1-77)				6. Bore hole dia. 16 in. Completion date 10/26/77 Well depth 35 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: Above xxxx Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 24.7 lbs./ft. Dia. 8 in. to 28 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .277		
5. Type and color of material				From	To	10. Screen: Manufacturer's name Layne
Top soil				0	2	Type St. Steel Dia. 8"
Brown silty sand				2	11	Slot/gauze #5 Length 10'
Fine to coarse sand to med. gravel				11	21	Set between 25 ft. and 35 ft.
Med. to coarse sand & gravel				21	35	Gravel pack? yes Size range of material Well Pack
Blue shale				35	37	11. Static water level: 16 ft. below land surface Date 10/26/77
						12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
						13. Water sample submitted: ____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 10/26/77
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
						15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. 110 Direction E. Type San Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Manufacturer's name Reda (Customer's) Model number ____ HP 1 1/2 Volts 220 Length of drop pipe 27 ft. capacity ____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name Wichita, Kansas License No. ____ Address Wichita, Kansas Signed Donald Aguirre Date 11/8/77 Authorized Representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		135 Feet West of SE Corner of Building; 2' North of South Property Fence				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5