

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

NE SE SW NE

1. Location of well:	County: <u>Sedgwick</u>	Fraction: <u><del>1/4</del> <del>1/4</del> <del>1/4</del> 1/4</u>	Section number: <u>6</u>	Township number: T <u>27</u> S	Range number: R <u>1E</u> E/W
2. Distance and direction from nearest town or city: <u>Wichita</u>		3. Owner of well: <u>T. Smith</u>			
Street address of well location if in city: <u>2635 Porter</u>		R.R. or street: <u>2635 Porter</u>			
		City, state, zip code: <u>Wichita Kans</u>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>6</u> in. Completion date: <u>3-30-76</u>	
				Well depth: <u>30</u> ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <u>Steel</u> Height: <u>12</u> in. or below Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>2-28</u> lbs./ft. Dia. <u>6</u> in. to <u>10</u> ft. depth Wall Thickness: inches or Dia. <u>12.5</u> in. to <u>30</u> ft. depth gage No. <u>10</u>	
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>Johnson</u>	
<u>Top Soil and sand</u>		<u>0'</u>	<u>10'</u>	Type <u>Steel</u> Dia. <u>1.25"</u>	
<u>Drive 1.25 pipe</u>		<u>10'</u>	<u>25'</u>	Slot/gauze <u>#10</u> Length <u>5'</u>	
<u>Sand Point</u>		<u>25'</u>	<u>30'</u>	Set between <u>25</u> ft. and <u>30</u> ft. ft. and ft.	
				Gravel pack? <input type="checkbox"/> Size range of material	
				11. Static water level: <u>20</u> ft. below land surface Date <u>3-30-76</u>	
				12. Pumping level below land surfaces: <u>20</u> ft. after <u>1</u> hrs. pumping <u>15</u> g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield <u>15</u> g.p.m.	
				13. Water sample submitted: <u>X</u> Yes <input type="checkbox"/> No Date	
				14. Well head completion: <u>12</u> inches above grade Pitless adapter	
				15. Well grouted? <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination: <u>West</u> Direction <u>Septic</u> Type ft. <u>60</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>21st Electric Inc.</u> <u>129</u> Business name License No. Address <u>512 W. 21st</u> Signed <u>John R. Harris</u> Date <u>4-6-76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5