


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 32	Township number T 27 S	Range number R 1 E E
2. Distance and direction from nearest town or city: Street address of well location if in city: 1923 S. Market				3. Owner of well: Mrs. R. Waldie R.R. or street: 1925 S. Market City, state, zip code: Wichita, KS 67211		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 				6. Bore hole dia. 1 in. Completion date 6-9-78 Well depth 29 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
LT Tan fine Sand				9. Casing: Material RMP Height Above or below Threaded <input type="checkbox"/> Welded Old Surface 14 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 6 in. to 2 ft. depth Wall Thickness: inches or Dia. 6 in. to 29 ft. depth gage No. 120		
				10. Screen: Manufacturer's name Sunflower Mfg Co Type RMP Dia. 6 1/8 Slot gauge 3/16 Length 5 ft Set between 24 ft. and 29 ft. Gravel pack? No Size range of material <input type="checkbox"/>		
LT. Brown med course gravel				11. Static water level: <input type="checkbox"/> mo./day/yr. 12 ft. below land surface Date 6-9-78		
				12. Pumping level below land surfaces: 12 ft. after 12 hrs. pumping 15 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 60 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: Pitless adapter 14 inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 15 Direction N Type sewer Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Valts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks: well in Basement			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Petheroe Pump & Well 295 Business name 227 W 27th Wichita KS License No. 1-9-78 Address 227 W 27th Wichita KS Signed [Signature] Date 6-9-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5