

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Jedgwick</u> Fraction <u>SE SE NENE</u> <u>NE 1/4 NE 1/4 NE 1/4</u> Section number <u>6</u> Township number <u>T 27</u> Range number <u>S R 1E</u> E/W	
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>2860 Wedgwood</u> 3. Owner of well: <u>Howard Hauge</u> R.R. or street: <u>2860 Wedgwood</u> City, state, zip code: <u>Wichita, KS.</u>	
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile Sketch map: <u>STREET 1.</u> <u>Garage</u>	
5. Type and color of material From To <u>topsoil</u> 0 12 <u>Sandy soil</u> 13 19 <u>gravel-med.</u> 20 30	
6. Bore hole dia. <u>11</u> in. Completion date <u>5-15-78</u> Well depth <u>30</u> ft.	
7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <u>PVC</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>2.75</u> lbs./ft. Dia. <u>5</u> in. to <u>30</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>30</u> ft. depth gage No. <u>258</u>	
10. Screen: Manufacturer's name <u>Wichita</u> Type <u>WC</u> Dia. <u>5.563</u> Slot/gauze <u>0.25</u> Length <u>5</u> Set between <u>25</u> ft. and <u>30</u> ft. Set between <u>25</u> ft. and <u>30</u> ft. Gravel pack? <u>No</u> Size range of material	
11. Static water level: <u>20</u> ft. below land surface Date <u>5-15-78</u>	
12. Pumping level below land surfaces: <u>20</u> ft. after <u>1</u> hrs. pumping <u>20</u> g.p.m. <u>20</u> ft. after <u>1</u> hrs. pumping <u>20</u> g.p.m. Estimated maximum yield <u>50</u> g.p.m.	
13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>5-15-78</u>	
14. Well head completion: <u>12</u> inches above grade	
15. Well grouted? <u>Yes</u> With: <u>Neat cement</u> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.	
16. Nearest source of possible contamination: <u>Septic</u> ft. <u>60</u> Direction <u>W</u> Type <u>Septic</u> Well disinfected upon completion? <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/>	
17. Pump: <u>Not installed</u> Manufacturer's name <u>Starline</u> Model number <u>IME</u> HP <u>5</u> Volts <u>220</u> Length of drop pipe <u>5</u> ft. capacity <u>5</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input checked="" type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	
19. Remarks: (Use a second sheet if needed)	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>2151 Electric</u> <u>129</u> Business name <u>512 W. 21/ Wichita</u> License No. <u>53078</u> Address <u>J. Hauge</u> Date <u>5-30-78</u> Signed <u>J. Hauge</u> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5