


1	LOCATION OF WATER WELL: <b>Sedgwick</b>	FRACTION <b>NW 1/4 NW 1/4 SW 1/4</b>	Section Number <b>7</b>	Township Number <b>T 27 S</b>	Range Number <b>R 1E E/W</b>
Distance and direction from nearest town or city street address of well if located within city? <b>1714 N. Sedgwick Wichita, Kansas</b>					
2	WATER WELL OWNER: <b>PEABODY, Sam</b> RR#, ST. ADDRESS, BOX #: <b>1714 N. Sedgwick</b> CITY, STATE, ZIP CODE: <b>Wichita, Kansas</b>			Board of Agriculture, Division of Water Resource Application Number:	
3	LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: <div style="text-align: center;">  </div>		4		
DEPTH OF COMPLETED WELL <b>40</b> ft. ELEVATION: Depth(s) groundwater Encountered <b>1</b> ft. <b>2</b> ft. <b>3</b> ft. WELL'S STATIC WATER LEVEL <b>17</b> FT. BELOW LAND SURFACE MEASURED ON mo/day/yr <b>06/18/1992</b> Pump test data: Well water was ft. after hours pumping gpm Est. Yield gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter <b>12</b> in. to <b>40</b> ft., and in. to ft. WELL WATER TO BE USED AS: <b>5</b> Public water supply <b>8</b> Air conditioning <b>11</b> Injection well <b>1</b> Domestic <b>3</b> Feedlot <b>6</b> Oil field water supply <b>9</b> dewatering <b>12</b> Other (Specify below) <b>2</b> Irrigation <b>4</b> Industrial <b>7</b> Lawn and garden only <b>10</b> Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes No <b>X</b> ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes <b>X</b> No					
5					
TYPE OF CASING USED: <b>1</b> Steel <b>3</b> RMP (SR) <b>5</b> Wrought iron <b>8</b> Concrete tile CASING JOINTS: Glued <b>X</b> Clamped <b>2</b> PVC <b>4</b> ABS <b>6</b> Asbestos-Cement <b>9</b> Other (Specify below) Welded <b>7</b> Fiberglass SDR-26 Threaded Blank casing Diameter <b>5</b> in. to <b>30</b> ft., Dia in. to ft., Dia in. to ft. Casing height above land surface <b>12</b> in., weight <b>2.29</b> lbs. / ft. Wall thickness or gauge No. <b>.214</b> TYPE OF SCREEN OR PERFORATION MATERIAL: <b>1</b> Steel <b>3</b> Stainless Steel <b>5</b> Fiberglass <b>7</b> PVC <b>10</b> Asbestos-cement <b>2</b> Brass <b>4</b> Galvanized steel <b>6</b> Concrete tile <b>9</b> ABS <b>11</b> other (specify) <b>12</b> None used (open hole) SCREEN OR PERFORATION OPENING ARE: <b>1</b> Continuous slot <b>3</b> Mill slot <b>5</b> Gauzed wrapped <b>8</b> Saw cut <b>11</b> None (open hole) <b>2</b> Louvered shutter <b>4</b> Key punched <b>6</b> Wire wrapped <b>9</b> Drilled holes <b>7</b> Torch cut <b>10</b> Other (specify) SCREEN-PERFORATION INTERVALS: from <b>30</b> ft. to <b>40</b> ft., From ft. to ft. GRAVEL PACK INTERVALS: from <b>24</b> ft. to <b>40</b> ft., From ft. to ft. from ft. to ft., From ft. to ft.					
6					
GROUT MATERIAL: <b>1</b> Neat cement <b>2</b> Cement grout <b>3</b> Bentonite <b>4</b> Other Grout Intervals: From <b>4</b> ft. to <b>24</b> ft., From ft. to ft., From ft. to ft. What is the nearest source of possible contamination: <b>1</b> Septic tank <b>4</b> Lateral lines <b>7</b> Pit privy <b>10</b> Livestock pens <b>14</b> Abandon water well <b>2</b> Sewer lines <b>5</b> Cess pool <b>8</b> Sewage lagoon <b>11</b> Fuel storage <b>15</b> Oil well/Gas well <b>3</b> Watertight sewer <b>6</b> Seepage pit <b>9</b> Feedyard <b>12</b> Fertilizer storage <b>16</b> Other (specify below) <b>13</b> Insecticide storage Direction from well? <b>East</b> How many feet? <b>80</b>					
7					
CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <b>06/18/1992</b> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <b>236</b> This Water Well Record was completed on (mo/day/yr) <b>8-25-92</b> Under the business name of <b>Harp Well &amp; Pump Service, Inc</b> by (signature) <i>Jane Frederick</i>					