


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEDGWICK	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 7	Township number T 27	Range number S R 1 E	E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 2162 W 17th WICHITA, KS				3. Owner of well: HOWARD TODDARD R.R. or street: 2162 W 17th City, state, zip code: WICHITA KS. 67263			
4. Locate with "X" in section below:  Sketch map: DRILLED 8" HOLE TO 10' THEN 6" TO 16.5 (H²O) THEN COMPLETED WELL WITH SAND BUCKET METHOD				6. Bore hole dia. 8 in. Completion date 7-18-77 Well depth 32.5 ft.			
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material RMP Height: Above or below Threated SL Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight 155 lbs./ft. Dia. 5 in. to 32.5 ft. depth Wall Thickness: inches or Dia. 5 in. to 32.5 ft. depth gage NO. 200			
				10. Screen: Manufacturer's name J+L Type RMP Dia. 5 INCH Slot/gauze .031 Length 7 FEET Set between 2.55 ft. and 32.5 ft. Gravel pack? NO size range of material			
				11. Static water level: 16.5 ft. below land surface Date 7-18-77			
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping NA g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 80 g.p.m.			
				13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date			
				14. Well head completion: Pitless adapter 12 Inches above grade			
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
				16. Nearest source of possible contamination: ft. 30 Direction N.E. Type CASE IRON SEWER Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation: 1300 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BEARDEN Pump & Well Business name 3142 MENTOR License No. WICHITA, KS Address OK W Bearden Date 8/18/77 Signed OK W Bearden Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5