


1 LOCATION OF WATER WELL: County: <u>Sedgwick</u>		Fraction <u>SE 1/4 SE 1/4 NE 1/4</u>	Section Number <u>9</u>	Township Number <u>T 27 S</u>	Range Number <u>R 1 E</u>
Distance and direction from nearest town or city street address of well if located within city? <u>1520 E 17th Wichita</u>					
2 WATER WELL OWNER: RR#, St. Address, Box # City, State, ZIP Code		<u>WNID- McAdams Park Apartments</u> <u>1520 E 17th N.</u> <u>Wichita KS 67214</u>		<u>WNID-15 Deep</u> Board of Agriculture, Division of Water Resources Application Number:	
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: <div style="text-align: center;">  </div>		4 DEPTH OF COMPLETED WELL: <u>31</u> ft. ELEVATION: Depth(s) Groundwater Encountered 1. <u>14.2</u> ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL <u>14.2</u> ft. below land surface measured on mo/day/yr <u>3-29-91</u> Pump test data: Well water was ft. after hours pumping gpm Est. Yield gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter <u>11.25</u> in. to <u>32</u> ft., and in. to ft. WELL WATER TO BE USED AS: 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only <u>10 Monitoring well</u> Was a chemical/bacteriological sample submitted to Department? Yes No <u>X</u> ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes No <u>X</u>			
5 TYPE OF BLANK CASING USED: 1 Steel 3 RMP (SR) <u>2 PVC</u> 4 ABS Blank casing diameter <u>2</u> in. to <u>21</u> ft., Dia in. to ft., Dia in. to ft. Casing height above land surface <u>0</u> in., weight <u>0.7</u> lbs./ft. Wall thickness or gauge No. <u>54490</u>		5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped Welded Threaded <u>X</u> 6 Asbestos-Cement 9 Other (specify below) 7 Fiberglass TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) 12 None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot <u>1 Mill slot 0.01</u> 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 3 Torch cut 10 Other (specify) 12 None used (open hole) SCREEN-PERFORATED INTERVALS: From <u>31</u> ft. to <u>21</u> ft., From ft. to ft. From ft. to ft., From ft. to ft. GRAVEL PACK INTERVALS: From <u>32</u> ft. to <u>19</u> ft., From ft. to ft. From ft. to ft., From ft. to ft.			
6 GROUT MATERIAL: 1 Neat cement <u>2 Cement grout</u> <u>3 Bentonite</u> 4 Other Grout Intervals: From <u>14</u> ft. to <u>surface</u> ft., From <u>19</u> ft. to <u>14</u> ft., From ft. to ft. What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) <u>Refinery</u> Direction from well? <u>NW</u> How many feet? <u>2500'</u>					
FROM TO LITHOLOGIC LOG FROM TO PLUGGING INTERVALS					
0	6	Silty CLAY			grout and casing height variance 9-22-91
6	11	Sandy CLAY			
11	13	Silty SAND Fine			
13	14	Silty CLAY			
14	30	Silty SAND nat to Fine w/ some coarse sand with depth			
30	31	Silty CLAY, olive green / gray			
31	32	Silty CLAY, dk gray / gray			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1) constructed</u> , (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>3-29-91</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>517</u> This Water Well Record was completed on (mo/day/yr) <u>4/22/91</u> under the business name of <u>Groundwater Technology</u> by (signature) <u>Albert Stout</u>					