

1 LOCATION OF WATER WELL: County: Sedgwick	Fraction SW ¼ SW ¼ NW ¼	Section Number 21	Township Number T 27 S	Range Number R 1 E
---	----------------------------	----------------------	---------------------------	-----------------------

2	WATER WELL OWNER:	The Coleman Company	
	RR#, St. Address, Box # :	250 N. St. Francis	Board of Agriculture, Division of Water Resources
	City, State, ZIP Code :	Wichita, KS 67214	Application Number:

N

NW	NE
SW	SE

S

Depth(s) Groundwater Encountered 14.54 ft. below land surface measured on mo/day/yr 10/9/89

WELL'S STATIC WATER LEVEL

Pump test data: Well water was _____ ft. after _____ hours pumping _____ gpm

Est. Yield _____ gpm: Well water was _____ ft. after _____ hours pumping _____ gpm

Bore Hole Diameter 6.5 in. to 33.0 ft., and _____ in. to _____ ft.

WELL WATER TO BE USED AS:

5 Public water supply	8 Air conditioning	11 Injection well
1 Domestic	3 Feedlot	6 Oil field water supply
2 Irrigation	4 Industrial	7 Lawn and garden only
		10 Monitoring well
		12 Other (Specify below)

Was a chemical/bacteriological sample submitted to Department? Yes _____ No X _____; If yes, mo/day/yr sample was submitted _____

Water Well Disinfected? Yes _____ No X _____

TYPE OF BLANK CASING USED:		5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded
2 PVC	4 ABS	7 Fiberglass		Threaded

Blank casing diameter 2.0 in. to 12.0 ft., Dia 2.0 in. to 23.0 ft., Dia in. to ft.

Casing height above land surface Flush in., weight lbs./ft. Wall thickness or gauge No. . . . Sch. 40

TYPE OF SCREEN OR PERFORATION MATERIAL:		X PVC	10 Asbestos-cement
1 Steel	3 Stainless steel	8 RMP (SR)	11 Other (specify)
2 Brass	4 Galvanized steel	9 ABS	12 None used (open hole)
5 Fiberglass	6 Concrete tile		

SCREEN OR PERFORATION OPENINGS ARE:

1 Continuous slot	X Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes	
		7 Torch cut	10 Other (specify)	

SCREEN-PERFORATED INTERVALS: From 12.0 ft. to 22.0 ft., From ft. to ft.

From 23.0 ft. to 33.0 ft., From ft. to ft.

GRAVEL PACK INTERVALS: From 11.0 ft. to 33.0 ft., From ft. to ft.

From ft. to ft., From ft. to ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Volclay Grout
Grout Intervals: From 1.0 ft. to 9.0 ft., From ft. to ft., From ft. to ft.
What is the nearest source of possible contamination:
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well
2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 13 Insecticide storage Industry
Direction from well? Northeast How many feet? 600

[illegible]

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 10/7/89 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 471 This Water Well Record was completed on (mo/day/yr) 10/9/89 under the business name of HWS Technologies by (signature) [Signature]