

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>Sedgwick</u>		<u>NE 1/4 SE 1/4 NE 1/4</u>	<u>19</u>	<u>T 27 S</u>	<u>R 1 E</u>
Distance and direction from nearest town or city street address of well if located within city? <u>403 N. Seneca, Wichita</u>					
2 WATER WELL OWNER:		Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box # : <u>1862 Craigshire</u>		Application Number:			
City, State, ZIP Code : <u>St Louis MO 63146</u>					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>20</u> ft. ELEVATION: <u>1298.14</u>			
		Depth(s) Groundwater Encountered <u>15</u> ft. 2. <u>14.05</u> ft. 3. <u>1-12-95</u>			
		WELL'S STATIC WATER LEVEL <u>14.05</u> ft. below land surface measured on mo/day/yr			
		Pump test data: Well water was <u>NA</u> ft. after <u>NA</u> hours pumping <u>NA</u> gpm			
		Est. Yield <u>NA</u> gpm: Well water was <u>NA</u> ft. after <u>NA</u> hours pumping <u>NA</u> gpm			
		Bore Hole Diameter <u>8</u> in. to <u>20</u> ft. and <u>20</u> in. to <u>20</u> ft.			
		WELL WATER TO BE USED AS:			
		5 Public water supply    8 Air conditioning    11 Injection well 1 Domestic    3 Feedlot    6 Oil field water supply    9 Dewatering    12 Other (Specify below) 2 Irrigation    4 Industrial    7 Lawn and garden only    10 Monitoring well <u>MW-3</u>			
		Was a chemical/bacteriological sample submitted to Department? Yes <u>No</u> If yes, mo/day/yr sample was submitted <u>No</u>			
5 TYPE OF BLANK CASING USED:		Water Well Disinfected? Yes <u>No</u>			
1 Steel    3 RMP (SR) <u>2 PVC</u> 4 ABS		CASING JOINTS: Glued <u>No</u> Clamped <u>No</u>			
Blank casing diameter <u>2</u> in. to <u>10</u> ft. Dia <u>10</u> in. to <u>10</u> ft. Dia <u>10</u> in. to <u>10</u> ft.		Casing height above land surface <u>0</u> in. weight <u>40</u> lbs./ft. Wall thickness or gauge No. <u>40</u>			
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC    10 Asbestos-cement 8 RMP (SR) 9 ABS    12 None used (open hole)			
SCREEN OR PERFORATION OPENINGS ARE:		5 Gauzed wrapped    8 Saw cut    11 None (open hole) 6 Wire wrapped    9 Drilled holes 7 Torch cut    10 Other (specify)			
SCREEN-PERFORATED INTERVALS:		From <u>20</u> ft. to <u>10</u> ft. From <u>10</u> ft. to <u>10</u> ft. From <u>20</u> ft. to <u>7.5</u> ft. From <u>7.5</u> ft. to <u>7.5</u> ft.			
GRAVEL PACK INTERVALS:		From <u>20</u> ft. to <u>7.5</u> ft. From <u>7.5</u> ft. to <u>7.5</u> ft.			
6 GROUT MATERIAL:		1 Neat cement    2 Cement grout    3 Bentonite    4 Other			
Grout Intervals: From <u>0</u> ft. to <u>10</u> ft. From <u>10</u> ft. to <u>7.5</u> ft. From <u>7.5</u> ft. to <u>7.5</u> ft.					
What is the nearest source of possible contamination:		10 Livestock pens    14 Abandoned water well 11 Fuel storage    15 Oil well/Gas well 12 Fertilizer storage    16 Other (specify below) 13 Insecticide storage			
1 Septic tank    4 Lateral lines    7 Pit privy 2 Sewer lines    5 Cess pool    8 Sewage lagoon 3 Watertight sewer lines    6 Seepage pit    9 Feedyard		How many feet? <u>50'</u>			
Direction from well? <u>NE</u>					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>0.5</u>	<u>Asphalt</u>			
<u>0.5</u>	<u>2.0</u>	<u>Silty clay</u>			
<u>2.0</u>	<u>20</u>	<u>Sand</u>			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>1-10-95</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>571</u> This Water Well Record was completed on (mo/day/yr) <u>1-16-95</u> under the business name of <u>BDAT Environmental</u> by (signature) <u>[Signature]</u>					