

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>Sedgwick</u>		<u>NE 1/4 SE 1/4 NE 1/4</u>	<u>19</u>	T <u>27</u> S	R <u>1</u> <u>EN</u>
Distance and direction from nearest town or city street address of well if located within city? <u>403 N. Seneca, Wichita</u>					
2 WATER WELL OWNER: <u>BDAT Environmental, Inc.</u>			Board of Agriculture, Division of Water Resources		
RR#, St. Address, Box #: <u>1862 Craigshire</u>			Application Number:		
City, State, ZIP Code: <u>St. Louis MO 63146</u>					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>20</u> ft. ELEVATION: <u>1297.98</u>			
		Depth(s) Groundwater Encountered <u>15</u> ft. 2. ft. 3. ft.			
		WELL'S STATIC WATER LEVEL <u>13.99</u> ft. below land surface measured on mo/day/yr <u>1-12-95</u>			
		Pump test data: Well water was <u>NA</u> ft. after <u>NA</u> hours pumping <u>NA</u> gpm			
		Est. Yield <u>NA</u> gpm: Well water was <u>NA</u> ft. after <u>NA</u> hours pumping <u>NA</u> gpm			
		Bore Hole Diameter <u>8</u> in. to <u>20</u> ft. and <u>20</u> in. to <u>20</u> ft.			
		WELL WATER TO BE USED AS:			
		1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well <u>MW-9</u>			
		Was a chemical/bacteriological sample submitted to Department? Yes <u>No</u> If yes, mo/day/yr sample was submitted <u>No</u>			
5 TYPE OF BLANK CASING USED:		Water Well Disinfected? Yes <u>No</u>			
1 Steel 3 RMP (SR) <u>2 PVC</u> 4 ABS		5 Wrought iron 8 Concrete tile CASING JOINTS: Glued <u>No</u> Clamped <u>No</u> 6 Asbestos-Cement 9 Other (specify below) Welded <u>No</u> 7 Fiberglass Threaded <u>No</u>			
Blank casing diameter <u>2</u> in. to <u>10</u> ft. Dia. <u>10</u> in. to <u>10</u> ft. Dia. <u>10</u> in. to <u>10</u> ft.		Casing height above land surface <u>0</u> in., weight <u>40</u> lbs./ft. Wall thickness or gauge No. <u>40</u>			
TYPE OF SCREEN OR PERFORATION MATERIAL:		1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 10 Asbestos-cement 11 Other (specify) <u>7 PVC</u> 12 None used (open hole)			
SCREEN OR PERFORATION OPENINGS ARE:		1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 7 Torch cut 10 Other (specify)			
SCREEN-PERFORATED INTERVALS:		From <u>20</u> ft. to <u>10</u> ft. From <u>10</u> ft. to <u>10</u> ft. From <u>20</u> ft. to <u>7.5</u> ft. From <u>7.5</u> ft. to <u>7.5</u> ft.			
GRAVEL PACK INTERVALS:		From <u>20</u> ft. to <u>7.5</u> ft. From <u>7.5</u> ft. to <u>7.5</u> ft.			
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other					
Grout Intervals: From <u>0</u> ft. to <u>10</u> ft. From <u>10</u> ft. to <u>7.5</u> ft. From <u>7.5</u> ft. to <u>7.5</u> ft.					
What is the nearest source of possible contamination:					
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage					
Direction from well? <u>SE</u>		How many feet? <u>75'</u>			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>2.0</u>	<u>Silty Clay</u>			
<u>2.0</u>	<u>20</u>	<u>SAND</u>			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>1-11-95</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>571</u> This Water Well Record was completed on (mo/day/yr) <u>1-16-95</u> under the business name of <u>BDAT Environmental</u> by (signature) <u>Boyle</u>					