

WELL RECORD

Well No. Water Farm Barker Producer Belleair Oil Corporation

Location S.W. 1/4 Sec. 4 Twp. 27 Rg. 18E

Elevation _____ State Kansas County Neosho

Kind (Oil, Gas, Water, Dry Hole) Water Contractor Johnstone & Sutcliffe

Producing formation _____ Top _____ Bottom _____

Shot with _____ qts. _____ from _____ to _____

Packer Set at _____ Kind _____ Size Elev 927

Liner _____ from _____ to _____ Perforated from _____ to _____

LOG

Thick-ness	Strata	Depth	Thick-ness	Strata	Depth
3	Soil	3	16	Shale	971
15	Clay	18	39	Blk. Shale	1010
6	Gravel	24	70	Lime	1080
19	Lime	43	158	Lime	1238
18	Shale	61	30	Shale	1268
139	Lime	200	4	Lime	1272
20	Shale	320			
7	Lime	337			
20	Shale	347			
8	Lime	355			
22	W. Shale	377			
12	Lime	389			
7	Shale	396			
29	Sand	425			
53	S. Shale	478			
3	Lime	481		Hard	
5	Shale	486			
24	Lime	510			
30	Shale	540			
17	Lime	557			
6	S. Shale	563			
4	Lime	567			
4	Shale	571			
89	W. Shale	660		Cased 576' of 10"	
2	Lime	662			
66	Shale	728			
26	Sandy	754			
36	Shale	790			
	B. Sand	820		Showing of Oil	
	Sand	955		Hole full Water	

Total Depth 1272

Open Hole _____

Casing _____ at _____

Casing _____ at _____

Casing _____ at _____

Cement _____

Tubing _____

Rods _____

Additional Information _____

971' Sandy

1010' top of Mississippi line

Water from 1080 to 1100

Set 8" casing--cemented with 300 sacks cement. Installed Reda Pump with 802' of 4". 2-18-52 pulled Reda Pump and ran 300' of 4".

1050

8/20/53 - pulled and replaced Reda pump. BOTTOM OF PUMP IS AT 1200 FEET.

Date Completed July 13, 1951
 Started, June 19, 1951

O. K.

Superintendent

OVER

April 9, 1955 - Top of the Reda Pump is at 1180 feet - S.L.M.

April 22, 1955 - Reda pump pulled out and repaired, pump ran back in, bottom of pump at 1230'. (1205' of 4") *exchanged ENTIRE PUMP, MOTOR, ETC. New cable installed - 4" pipe looked good.*

May 2, 1957 - Pulled the entire unit, protector head was burned. Motor and protector were full of water. Pulled by Parrish and same unit run back.

May 7, 1957 - New unit run by Parrish, Low voltage. The power company is stepping up the transformer.

July 24, 1958 - Lightning struck switch board burning up the No.1 controls and burning up the motor. Complete new unit run by Moore.

October 31, 1958 - Pulled to the top of the hole and changed two bad joints of 4" tubing and rerun. Done by Mr.H.B.Cole.

January 1, 1959 - Pulled entire unit, spliced cable in three places, rerun same pump with new motor and protector. Damage was caused by a break in the city power lines Sunday, Dec. 21, 1958 at approximately 4:30 A.M. The powerline break single phased our system and burned three 1½HP Electric motors on pumping units as well as the Reda Pump motor. Thr 100 HP motors pulling the Aldrich pumps kicked out and were not damaged and Reda No.2 was off at the time.

*Dec. 1960 Pulled Power Cable in two at 29th St. of 4" Tubing & pulled 35 ft tubing
9 ft of 4" Tubing 500' of power cable & Reda Pump left in well
Flushed out by Sitchiffe Pipe Supply.*