



USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 10	Township number T 27	Range number S R 2 E	E/W
2. Distance and direction from nearest town or city:		4 E 2 N, Wichita		3. Owner of well: Ray Morrisette R.R. or street: 1146 Amistad BLVD City, state, zip code: UNIVERSAL City Texas			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 8/19/78 Well depth 100 ft.			
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Soil		0		5		9. Casing: Material PS Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 100 lbs./ft. Dia. 6 in. to 100 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1175	
Rock		5		15		10. Screen: Manufacturer's name Sunflower Plastics Type 100 Dia. 6 Slot/gauze 1/16 Length 30 Set between 100 ft. and 80 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 5/8	
Lime		15		60		11. Static water level: <input type="checkbox"/> mo./day/yr. 40 ft. below land surface Date 9/25/78	
Shale		60		100		12. Pumping level below land surfaces: 50 ft. after 10 hrs. pumping 50 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 57 g.p.m.	
						13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 9/25/78	
						14. Well head completion: 18 inches above grade <input type="checkbox"/> Pitless adapter	
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
						16. Nearest source of possible contamination: ft. 500 Direction S Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter Well Drill 251A Business name P2 Box 30 License No. 1/4 NE 1/4 NE 1/4 Address Charlton, winter Signed 9/27/78 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5