

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>Salzwick</u>		<u>NW</u> $\frac{1}{4}$ <u>NW</u> $\frac{1}{4}$ <u>SW</u> $\frac{1}{4}$	<u>20</u>	T <u>27</u> S	R <u>2</u> <u>EW</u>
Distance and direction from nearest town or city street address of well if located within city? <u>102 S. Rock Road Wichita KS</u> <u>MW-4</u>					
2 WATER WELL OWNER:		Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box # : <u>Box 2159</u>		Application Number:			
City, State, ZIP Code : <u>Dallas TX 75221</u>					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>30</u> ft. ELEVATION:			
		Depth(s) Groundwater Encountered 1. <u>17</u> ft. 2. ft. 3. ft.			
		WELL'S STATIC WATER LEVEL <u>14.2</u> ft. below land surface measured on mo/day/yr <u>2-7-89</u>			
		Pump test data: Well water was ft. after hours pumping gpm			
		Est. Yield gpm: Well water was ft. after hours pumping gpm			
		Bore Hole Diameter: <u>12</u> in. to <u>30</u> ft., and in. to ft.			
		WELL WATER TO BE USED AS:			
		5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only <u>10</u> Monitoring well			
		Was a chemical/bacteriological sample submitted to Department? Yes No <u>X</u> If yes, mo/day/yr sample was submitted			
		Water Well Disinfected? Yes No <u>X</u>			
5 TYPE OF BLANK CASING USED:					
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped <u>2</u> PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded Blank casing diameter <u>4</u> in. to <u>15</u> ft., Dia. in. to ft., Dia. in. to ft. Casing height above land surface <u>0</u> in., weight lbs./ft. Wall thickness or gauge No. <u>5440</u> TYPE OF SCREEN OR PERFORATION MATERIAL: <u>0</u> PVC 10 Asbestos-cement 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)					
SCREEN OR PERFORATION OPENINGS ARE:					
1 Continuous slot <u>3</u> Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 7 Torch cut 10 Other (specify)					
SCREEN-PERFORATED INTERVALS: From <u>15</u> ft. to <u>30</u> ft., From ft. to ft.					
GRAVEL PACK INTERVALS: From <u>10</u> ft. to <u>30</u> ft., From ft. to ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout <u>3</u> Bentonite 4 Other					
Grout Intervals: From <u>Surface</u> ft. to <u>10</u> ft., From ft. to ft., From ft. to ft.					
What is the nearest source of possible contamination:					
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon <u>12</u> Fertilizer storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 13 Insecticide storage 16 Other (specify below) Direction from well? <u>East</u> How many feet? <u>75</u>					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	8	DK Gray, moist, silty CLAY			
8	17	Lt Brown, wet, silty CLAY			
17	30	Lt Brown, saturated SANDY CLAY			
Grout variance and casing height variance for flush mount covers grouted 2-21-89 by Darrel Plummer					
Installed water tight locking caps.					
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1)</u> constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>2-6-89</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>426</u> <u>517</u> This Water Well Record was completed on (mo/day/yr) <u>3/6/89</u> under the business name of <u>Crownburst Leasing Co.</u> by (signature) <u>Oswald</u>					