


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction NW SE SW SW NE 1/4 SW 1/4 SW 1/4	Section number 25	Township number T 27 S	Range number R 2E E/W		
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: City, state, zip code:					
1508 Robin Red Circle Wichita, Kansas			Dale Bitler 1508 Robin Red Circle Wichita, Kansas					
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 			6. Bore hole dia. 11 in. Completion date Well depth 55 ft. 3-14-77		
5. Type and color of material			From	To	7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary			
Topsoil			0	2	8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other			
Shale (Gray)			2	50	9. Casing: Material styrene Weight: Above or below Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC ☐ Weight 12 lbs./ft. Dia. 5 in. to 55 ft. depth Wall Thickness: inches or Dia. 5 in. to 55 ft. depth Gauge No. .200			
Limestone			50	55	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot 1/4" .06 Length 40' Set between 15 ft. and 55 ft. ft. and 55 ft. and 55 ft. Gravel pack? yes Size range of material 1-1/8"			
					11. Static water level: 15 ft. below land surface Date 3-14-77			
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
					13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____			
					14. Well head completion: 12 capped ____ Pitless adapter ____ Inches above grade			
					15. Well grouted? yes With: ____ Neat cement ____ Bentonite ☒ Concrete Depth: From 40" ft. to 14 ft. OK			
					16. Nearest source of possible contamination: ft. 100 Direction East Type Sewer Well disinfected upon completion? ☒ Yes ____ No			
					17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other			
(Use a second sheet if needed)								
18. Elevation:		19. Remarks:						
Topography: ____ Hill ☒ Slope ☒ Upland ____ Valley								
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 3-18-77 Authorized representative						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5