

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620


1 Location of well:	County Butler	Township name	Fraction NE 1/4 NE 1/4	Section number 1	Town number 298	Range number 3 E
---------------------	----------------------	---------------	-------------------------------	-------------------------	------------------------	-------------------------

Distance and direction from nearest town or city: **3 1/2 W 4 N**
OF Augusta Kan

3 Owner of well: **Windermer Farms**
Address: **P.O. Box 52 Towanda**

Street address of well location if in city:

Locate with "X" in section below:



Sketch map:

4 Well depth: 120 ft. Date of completion 5/11/80
Well diameter 8 in.
5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
7 Casing: Material PS Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. Diam. 9 1/4 Weight 200 lbs./ft. 5 in. to 120 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No — in. to — ft. depth 1214
8 Screen: Manufacturer ScenFlower Type 200 Dia. 5 Slot/gauze 1/16 Length 20 Set between 55 ft. and 75 ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material —
9 Static water level: 50 ft. below land surface Date 5/11/80
10 Pumping level below land surfaces 60 ft. after 1 hrs. pumping Ball g.p.m. — ft. after — hrs. pumping 30 g.p.m. Estimated maximum yield 30 g.p.m.
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —
12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> — Depth: From 0 ft. to 10 ft.
14 Nearest source of possible contamination: ft. 150 Direction E Type Logan, W Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name — Model number — HP — Volts — Length of drop pipe — ft. capacity — g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation (use a second sheet if needed)

16 Remarks: elevation

Topography:
 Hill
 Slope
 Upland
 Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this
report is true to the best of my knowledge and belief.

Winter Well Drill 251
Business name **P.O. Box 30 Augusta Kan** License No. **—**
Address **—** Signed **Charles Winter** Date **9/18/80**
Authorized representative **—**