

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X. Location of well:		County: <i>Batler</i>	Fraction: <i>NW 1/4 SW 1/4 NE 1/4</i>	Section number: <i>1</i>	Township number: <i>T 27 S R 30</i>	Range number: <i>30</i>
X. Distance and direction from nearest town or city:		<i>4W 2N</i>		3. Owner of well: <i>John Stephenson</i>		
Street address of well location if in city:		<i>OF Andover</i>		R.R. or street: <i>16205</i>	City, state, zip code: <i>EAST Pawnee Wichita 67230</i>	
4. Locate with "X" in section below:		Sketch map: <i>X Septic</i>		6. Bore hole dia. <u>7</u> in. Completion date <u>7/27/74</u> Well depth <u>100</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input checked="" type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
<i>Soil</i>		<i>0</i>	<i>5</i>	9. Casing: Material <u>PS</u> Height: Above or below Threaded <input type="checkbox"/> Welded <u>30</u> Surface <u>18</u> in. RMP <u>X</u> PVC Weight <u>120</u> lbs./ft. Dia. <u>5</u> in. to <u>100</u> ft. depth Wall Thickness: inches or Dia. <u>—</u> in. to <u>—</u> ft. depth gage No. <u>175</u>		
<i>Clay</i>		<i>5</i>	<i>20</i>	10. Screen: Manufacturer's name <u>SGN Flower</u>		
<i>Shale</i>		<i>20</i>	<i>50</i>	Type <u>100</u> Dia. <u>5</u> Slot/gauze <u>1/16</u> Length <u>20</u> Set between <u>10</u> ft. and <u>90</u> ft. ft. and <u>—</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>5/8</u>		
<i>Blue Shale</i>		<i>50</i>	<i>90</i>	11. Static water level: <u>50</u> ft. below land surface Date <u>14/5/74</u>		
<i>Sandy Lime</i>		<i>90</i>	<i>90</i>	12. Pumping level below land surfaces: <u>60</u> ft. after <u>1</u> hrs. pumping <u>9 p.m.</u> <u>—</u> ft. after <u>—</u> hrs. pumping <u>9 p.m.</u> Estimated maximum yield <u>30</u> g.p.m.		
<i>Shale</i>		<i>90</i>	<i>100</i>	13. Water sample submitted: <u>mo./day/yr.</u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>—</u>		
				14. Well head completion: <u>Pitless adapter</u> Inches above grade		
				15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. <u>150</u> Direction <u>N</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>—</u> Model number <u>—</u> HP <u>—</u> Volts <u>—</u> Length of drop pipe <u>—</u> ft. capacity <u>—</u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
		19. Remarks: <i>Owner to install concrete slab around well head</i>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Winter Well Drill 251A</i> Business name <u>P2 Box 30</u> License No. <u>—</u> Address <u>—</u> Signed <u>Charles Winter</u> Date <u>5/5/74</u> Authorized representative <u>—</u>		