

1. Location of well:	County Butler	Fraction SW 1/4 SE 1/4	Section number 14	Township number T 27 S	Range number R 3E E/W
2. Distance and direction from nearest town or city: 3 1/2 East of Andover on Central, Street address of well location if in city: North side of Rd.			3. Owner of well: Hartman Homes R.R. or street: 6416 East. Central City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N Andover, Kansas Sketch map: <div style="text-align: center;"> </div>			6. Bore hole dia. 11 in. Completion date: 5-16-77 Well depth 140 ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 44 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. 5 in. to 140 ft. depth gage No. .200		
			10. Screens: Manufacturer's name Sunflower Plastic Type Styrene Dia. 5" Slot/gauge .06 Length 60 Set between 80 ft. and 140 ft. Gravel pack? yes ft. and 1-1/8" Size range of material		
			11. Static water level: 78 ft. below land surface Date 5-16-77 mo./day/yr.		
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: _____ Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.		
			16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: _____ Not installed Manufacturer's name Sta-Rite Model number 20P4D02 HP 3/4 Volts 230 Length of drop pipe 120 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal 8-12-77 <input type="checkbox"/> Other		
			18. Elevation:		
			19. Remarks: Septic System not installed when the well was drilled. No apparent source for contamination.		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. _____ Address M. Arnold Signed _____ Date 8-12-77 Authorized representative		
			(Use a second sheet if needed)		