


1 LOCATION OF WATER WELL		Fraction	Section Number		Township Number		Range Number	
County: BUTLER		<input checked="" type="checkbox"/> NE 1/4 <input type="checkbox"/> NW 1/4 <input type="checkbox"/> SE 1/4	2C		T 27 S		R 3E E11	
Distance and direction from nearest town or city? 1 1/2 S. of Andover Rd., 1/2 N. of Andover				Street address of well if located within city? #10 Yorktown Andover, Kansas				
2 WATER WELL OWNER:		W. J. Combs Const. SPEC HOUSE						
RR#, St. Address, Box # :		#2 Williamsburg		Board of Agriculture, Division of Water Resources				
City, State, ZIP Code :		Andover, Kansas		Application Number:				
3 DEPTH OF COMPLETED WELL: 7.5 ft. Bore Hole Diameter: 11 in. to ft., and in. to ft.								
Well Water to be used as:								
1 Domestic		3 Feedlot		6 Oil field water supply		9 Dewatering		
2 Irrigation		4 Industrial		7 Lawn and garden only		10 Observation well		
Well's static water level: 20 ft. below land surface measured on		6 month		5 day		1979 year		
Pump Test Data		Well water was ft. after		hours pumping		gpm		
Est. Yield gpm:		Well water was ft. after		hours pumping		gpm		
4 TYPE OF BLANK CASING USED:								
1 Steel		2 RMP (SB)		5 Wrought iron		8 Concrete tile		
2 PVC		4 ABS		6 Asbestos-Cement		9 Other (specify below)		
				7 Fiberglass		Casing Joints: Glued <input checked="" type="checkbox"/> Clamped		
Blank casing dia 5 in. to 20 ft. Dia		in. to ft. Dia		in. to ft. Dia		Welded		
Casing height above land surface 12 in., weight		lbs./ft. Wall thickness or gauge No		.200		Threaded		
TYPE OF SCREEN OR PERFORATION MATERIAL:								
1 Steel		3 Stainless steel		5 Fiberglass		8 RMP (SB)		
2 Brass		4 Galvanized steel		6 Concrete tile		9 ABS		
						10 Asbestos-cement		
						11 Other (specify)		
						12 None used (open hole)		
Screen or Perforation Openings Are:								
1 Continuous slot		3 Mill slot		5 Gauzed wrapped		8 Saw cut .06		
2 Louvered shutter		4 Key punched		6 Wire wrapped		9 Drilled holes		
				7 Torch cut		10 Other (specify)		
Screen-Perforation Dia 5 in. to 7.5 ft. Dia		in. to ft. Dia		in. to ft. Dia		in. to ft. Dia		
Screen-Perforated Intervals:		From 20 ft. to 7.5 ft.		From ft. to ft.		From ft. to ft.		
Gravel Pack Intervals:		From 14 ft. to 7.5 ft.		From ft. to ft.		From ft. to ft.		
5 GROUT MATERIAL:								
1 Neat cement		2 Cement grout		3 Bentonite		4 Other		
Grouted Intervals: From 40 ft. to 14 ft.		From ft. to ft.		From ft. to ft.		From ft. to ft.		
What is the nearest source of possible contamination: Septic System not installed								
1 Septic tank		4 Cess pool at this time		7 Sewage lagoon		10 Fuel storage		
2 Sewer lines		5 Seepage pit		8 Feed yard		11 Fertilizer storage		
3 Lateral lines		6 Pit privy		9 Livestock pens		12 Insecticide storage		
						13 Watertight sewer lines		
						14 Abandoned water well		
						15 Oil well/Gas well		
						16 Other (specify below)		
						No apparent source		
Direction from well How many feet ? Water Well Disinfected? Yes <input checked="" type="checkbox"/> No								
Was a chemical/bacteriological sample submitted to Department? Yes No <input checked="" type="checkbox"/> If yes, date sample was submitted month day year Pump Installed? Yes No <input checked="" type="checkbox"/>								
If Yes: Pump Manufacturer's name Model No. HP Volts								
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.								
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other								
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 6 month 5 day 1979 year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236 This Water Well Record was completed on 7 month 31 day 1979 year under the business name of Harp Well & Pump Service, Inc. by (signature) M. Arnold								
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG		FROM TO LITHOLOGIC LOG				
		0 3 Topsoil						
		3 18 Clay						
		18 53 Brown Shale						
		53 75 Grey Shale						
ELEVATION: Flat Ground								
Depth(s) Groundwater Encountered 1 ft. 2 ft. 3 ft. 4 ft. (Use a second sheet if needed)								
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.								