


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>BUTLER</b>	Fraction 1/4 SW 1/4 NW 1/4	Section number 21	T 27 S R 3E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 mile E. of Andover and 1/2 N. of Hyway 54. Bicentennial		3. Owner of well: R.R. or street: City, state, zip code:	Dale Blunt 1701 S. Erie Wichita, Kansas
4. Locate with "X" in section below:  	Sketch map: <b>Addition. Andover, Kansas</b>		6. Bore hole dia. <u>11</u> in. Completion date <u>6-26-78</u> Well depth <u>65</u> ft.	
5. Type and color of material	From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<b>Topsoil</b>	0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<b>Clay</b>	3	10	9. Casing: Material <b>Styrene</b> Height: Above or <u>below</u> Threaded <input type="checkbox"/> Welded <u>g1</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC Weight <u>16</u> lbs./ft. Dia. <u>5</u> in. to <u>65</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>ft.</u> depth <u>gage No. .200</u>	
<b>Brown Shale</b>	10	28	10. Screen: Manufacturer's name <b>Sunflower Plastic</b> Type <b>styrene</b> Dia. <u>5"</u> Slot/pole <u>.06</u> Length <u>40'</u> Set between <u>25</u> ft. and <u>65</u> ft. ft. and <u>ft.</u> Gravel pack? <b>yes</b> Size range of material <u>1/4-1/8"</u>	
<b>Gray Shale</b>	28	65	11. Static water level: <u>26</u> ft. below land surface Date <u>6-26-78</u>	
			12. Pumping level below land surfaces: <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>g.p.m.</u>	
			13. Water sample submitted: Yes <input type="checkbox"/> No <input type="checkbox"/> Date <u>mo./day/yr.</u>	
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade	
			15. Well grouted? <b>yes</b> 1-2 Fine Sand Mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>6</u> ft. to <u>16</u> ft.	
			16. Nearest source of possible contamination: <u>ft.</u> <u>Direction</u> Type <b>NONE</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u></u> Model number <u></u> HP <u></u> Volts <u></u> Length of drop pipe <u>ft.</u> capacity <u>g.p.m.</u> Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)			18. Elevation:  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	
19. Remarks: <b>Flat Ground</b>  <b>Septic system not installed at this time.</b> <b>No apparent source for contamination.</b>  <b>Pump not installed at this time.</b>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Harp Well &amp; Pump</b> <u>236</u> Business name <u></u> License No. <u></u> Address <u>Wichita, Kansas</u> <u>67209</u> Signed <u>M. Arnold</u> Date <u>9-30-78</u> (Authorized representative)	