

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County BUTLER	Fraction NE 1/4 SW 1/4 NW 1/4	Section number 23	Township number T 27 S	Range number R 3 E
2. Distance and direction from nearest town or city: 3/4 so SW of Augusta KS			3. Owner of well: Keith Meyer R.R. or street: RS Box 120 K City, state, zip code: Augusta KS		
4. Locate with "X" in section below:			Sketch map:		
5. Type and color of material			6. Bore hole dia. 8-5/8 in. Completion date 4-13-79 Well depth 120 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PBS Height: Above or below Threaded <input type="checkbox"/> Welded flue Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 10 lbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or Dia. 5 in. to 120 ft. depth gage No. 200		
			10. Screen: Manufacturer's name SUNFLOWER MEP Type RMP Dia. 5" Slot/gauze 264 Length 10' Set between 110 ft. and 120 ft. Gravel pack? yes Size range of material 8-36		
			11. Static water level: 88 ft. below land surface Date 4-13-79 mo./day/yr.		
			12. Pumping level below land surfaces: NA ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
			13. Water sample submitted: X Yes X No Date ____		
			14. Well head completion: X Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 14 ft. to 4 ft.		
			16. Nearest source of possible contamination: septic ft. 65 Direction SW Type septic <input checked="" type="checkbox"/> Well disinfected upon completion? X Yes ____ No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Remarks:		
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			owner will install concrete slab		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Braddy water wells 363 Business name Braddy License No. ____ Address R2 Douglass KS Signed Richard Braddy Date 4-13-79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5