


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Butler	Fraction 1/4NW 1/4NW 1/4	Section number 23	Township number T 27	Range number S R 3E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 North of the Augusta airport Augusta, Kansas				3. Owner of well: Bill J. Poore Construction R.R. or street: R#1 Augusta, Kansas City, state, zip code:		
4. Locate with "X" in section below: 				6. Bore hole dia. 11 in. Completion date 7-22-78 Well depth 114 ft.		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material styrene Height: Above or below 66 ft. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 14 ft. depth Wall Thickness: inches or Dia. 5 in. to 14 ft. depth gage No. 200		
				10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauze .06 Length 34 Set between 80 ft. and 114 ft. ft. and 114 ft. Gravel pack? yes Size range of material 1/2-1/8"		
				11. Static water level: 80 ft. below land surface Date 7-22-78 mo./day/yr.		
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
				13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____		
				14. Well head completion: 12 capped ____ Pitless adapter ____ inches above grade		
				15. Well grouted? yes 1-2 fine sand mix With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40 ft. to 14 ft.		
				16. Nearest source of possible contamination: None ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No		
(Use a second sheet if needed)				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 7-30-78 Authorized representative		
				18. Elevation:		
				19. Remarks: Septic system not installed at this time No apparent source for contamination		
				Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope ____ Upland ____ Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5