

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: Butler		NW 1/4 NE 1/4 SW 1/4	24	T 27 S	R 3 E
Distance and direction from nearest town or city? 3 W 1/2 of Augusta			Street address of well if located within city?		
2 WATER WELL OWNER: RIAN Watson					
RR#, St. Address, Box #: R3 BOX 110			Board of Agriculture, Division of Water Resources		
City, State, ZIP Code: Augusta KS 67010			Application Number:		
3 DEPTH OF COMPLETED WELL: 150 ft. Bore Hole Diameter: 9 in. to 1.50 ft., and ... in. to ... ft.					
Well Water to be used as:					
☒ Domestic		5 Public water supply		8 Air conditioning	
☐ Irrigation		6 Oil field water supply		9 Dewatering	
☐ Feedlot		7 Lawn and garden only		10 Observation well	
☐ Industrial				11 Injection well	
				12 Other (Specify below)	
Well's static water level: 101 ft. below land surface measured on 10 month 22 day 79 year					
Pump Test Data: NA Well water was ... ft. after ... hours pumping ... gpm					
Est. Yield: ... gpm: Well water was ... ft. after ... hours pumping ... gpm					
4 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)		5 Wrought iron	
☒ PVC		4 ABS		6 Asbestos-Cement	
				7 Fiberglass	
				8 Concrete tile	
				9 Other (specify below)	
Casing Joints: Glued ☒ Clamped ...					
Welded ...					
Threaded ...					
Blank casing dia: 5 in. to 1.30 ft., Dia ... in. to ... ft., Dia ... in. to ... ft.					
Casing height above land surface: 24 in., weight ... lbs./ft. Wall thickness or gauge No. 14"					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel		5 Fiberglass	
☒ PVC		4 Galvanized steel		6 Concrete tile	
				8 RMP (SR)	
				9 ABS	
				10 Asbestos-cement	
				11 Other (specify)	
				12 None used (open hole)	
Screen or Perforation Openings Are:					
1 Continuous slot		3 Mill slot		5 Gauzed wrapped	
☒ Saw cut		6 Wire wrapped		8 Saw cut	
2 Louvered shutter		4 Key punched		9 Drilled holes	
				10 Other (specify)	
				11 None (open hole)	
Screen-Perforation Dia: 5 in. to 1.50 ft., Dia ... in. to ... ft., Dia ... in. to ... ft.					
Screen-Perforated Intervals: From 1.30 ft. to 1.50 ft., From ... ft. to ... ft., From ... ft. to ... ft.					
Gravel Pack Intervals: From 1.50 ft. to 1.10 ft., From ... ft. to ... ft., From ... ft. to ... ft.					
5 GROUT MATERIAL:					
1 Neat cement		☒ Cement grout		3 Bentonite	
4 Other					
Grouted Intervals: From 1.10 ft. to 90 ft., From ... ft. to ... ft., From ... ft. to ... ft.					
What is the nearest source of possible contamination:					
☒ Septic tank		4 Cess pool		7 Sewage lagoon	
2 Sewer lines		5 Seepage pit		8 Feed yard	
3 Lateral lines		6 Pit privy		9 Livestock pens	
				10 Fuel storage	
				11 Fertilizer storage	
				12 Insecticide storage	
				13 Watertight sewer lines	
				14 Abandoned water well	
				15 Oil well/Gas well	
				16 Other (specify below)	
Direction from well: SO. How many feet: 140' ? Water Well Disinfected? Yes ☒ No ☒					
Was a chemical/bacteriological sample submitted to Department? Yes ☒ No ☒ If yes, date sample was submitted ... month ... day ... year					
Pump Installed? Yes ☒ No ☒					
If Yes: Pump Manufacturer's name ... Model No. ... HP ... Volts ...					
Depth of Pump Intake ... ft. Pumps Capacity rated at ... gal./min.					
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other					
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was ☒ constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 10 month 22 day 79 year					
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 363					
This Water Well Record was completed on 10 month 23 day 79 year under the business name of Braddy Water Wells by (signature) Richard Braddy					
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG		FROM TO LITHOLOGIC LOG	
		0 3 clay brown		110 134 shale Rusty Red	
		3 9 clay Redish brown		134 150 shale gray	
		9 28 limestone yellow			
		28 44 lime with clay yellow			
		44 49 shale light gray			
		49 59 shale lavender			
		59 79 shale yellow gray			
		79 94 limestone yellow			
		94 110 shale gray			
				The water at 98' has oil residue in it because of this it was sealed out	
ELEVATION: Slope					
Depth(s) Groundwater Encountered 1. 98 ft. 2. 138 ft. 3. ... ft. 4. ... ft. (Use a second sheet if needed)					

OFFICE USE ONLY

T

27

R

3

EW

SEC.

24

NW 1/4

NE 1/4

SW 1/4