

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BILLED TO: WILSON CONTRACTORS

1. Location of well:	County BUTLER	Fraction 1/4 SW 1/4 NW 1/4	Section number 33	Township number 27	Range number 3E	E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 mile south of hwy 54 and 1 1/8 miles east of the			3. Owner of well: R.R. or street: City, state, zip code:	City of Andover Wastewater Treatment Facility Andover, Kansas	
4. Locate with "X" in section below:	Sketch map: Andover Road, $\frac{1}{2}$ South. Andover, Ks.			6. Bore hole dia. 11 in. Completion date Well depth 70 ft. 11-3-76		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Topsoil	0	3		9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.96 lbs./ft. Dia. 6 in. to 70 ft. Wall Thickness: inches or Dia. 6 in. to 70 ft. depth gage No. .316		
Clay	3	16		10. Screen: Manufacturer's name PVC NSF approved 200 PSI Type PVC 200PSI Dia. 6" Slot/gauge .06 Length 35' Set between 35 ft. and 70 ft. ft. and 70 ft. Gravel pack? yes Size range of material 1/4-1/8"		
Green Shale	16	31		11. Static water level: 30 ft. below land surface Date 11-3-76		
Blue Shale	31	70		12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
				13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
				14. Well head completion: X Pitless adapter 18 Inches above grade		
				15. Well grouted? yes 1-2 fine sand mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.		
				16. Nearest source of possible contamination: ft. 40 Direction SE Type pool tank Well disinfected upon completion? X Yes No		
				17. Pump: Manufacturer's name customer's pump Not installed Model number unknown HP 1/2 Volts 230 Length of drop pipe 45 ft. capacity 10 g.p.m. Type: X Submersible Turbine <input type="checkbox"/> Jet Reciprocating <input type="checkbox"/> Centrifugal Other		
(Use a second sheet if needed)				18. Elevation:	19. Remarks: Flat Ground	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. Address M. Arnold Signed 3-15-79 Date Authorized representative 3-15-79
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Installed customer's submersible pump and 42 gallon pressure tank. From # 8 above - Water not used for drinking, water used to water mechanical seal and washing sidewalk.					