

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location of well:		County BUTLER	Fraction 1/4NW 1/4 SW 1/4	Section number 18	Township number T 27 S R 4E E/W	Range number															
Distance and direction from nearest town or city: #3 Hillcreek Andover, Kansas			3. Owner of well: R.O. Arnold Construction																		
Street address of well location if in city:			R.R. or street: 14405 Willowbend Circle																		
			City, state, zip code: Wichita, Kansas																		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map:																		
<table border="1"><tr><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td></tr></table>																			6. Bore hole dia. 11 in. Completion date _____ Well depth 110 ft. 5-26-78		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																		
			9. Casing: Material styrene Height: Above or below Threaded _____ Welded gl Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 110 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .200																		
			10. Screen: Manufacturer's name _____ Sunflower Plastic Type styrene Dia. 5" Slot .06 Length 70' Set between 40 ft. and 110 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4-1/8"																		
			11. Static water level: _____ mo./day/yr. 34 ft. below land surface Date 5-26-78																		
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.																					
13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____																					
14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade																					
15. Well grouted? yes 1-2 Fine Sand Mix With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.																					
16. Nearest source of possible contamination: septic ft. 70 Direction East Type tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																					
17. Pump: _____ Not installed Manufacturer's name Sta-Rite Model number 20P4D02 HP 3/4 Volts 230 Length of drop pipe 90 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other																					
(Use a second sheet if needed)																					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 5-22-78 Authorized representative																		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley																					

22
4
18
1/4
1/4
1/4
NWSE