

1 LOCATION OF WATER WELL:		FRACTION		Section Number		Township Number		Range Number	
Sedgwick		SE 1/4 NE 1/4 NE 1/4		31		T 28 S		R 1E E/W	
Distance and direction from nearest town or city street address of well if located within city?									
63rd South and Seneca (South Seneca Pump Station) Wichita, Kansas									
WATER WELL OWNER:		WICHITA, CITY OF				Board of Agriculture, Division of Water Resource			
RR#, ST. ADDRESS, BOX #:		455 N. Main				Application Number:			
CITY, STATE, ZIP CODE:		Wichita, Kansas 67203							
LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 35 ft. ELEVATION:							
		Depth(s) groundwater Encountered 1 ft. 2 ft. 3 ft.							
		WELL'S STATIC WATER LEVEL 11 FT. BELOW LAND SURFACE MEASURED ON 03/07/1997							
		Pump test data: Well water was ft. after hours pumping gpm							
		Est. Yield gpm: Well water was ft. after hours pumping gpm							
		Bore Hole Diameter 14 in. to 35 ft. and in. to ft.							
WELL WATER TO BE USED AS:		5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well							
Was a chemical/bacteriological sample submitted to Department? Yes No ☒ ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes ☒ No									
5 TYPE OF CASING USED:		CASING JOINTS: Glued ☒ Clamped							
1 Steel 3 RMP (SR)		Welded							
2 PVC 4 ABS		Threaded							
Blank casing Diameter 6 in. to 25 ft., Dia in. to ft., Dia in. to ft.		Weight 3.68 lbs. / ft. Wall thickness or gauge No. .280							
Casing height above land surface 36 in.,		7 PVC .060" slot 10 Asbestos-cement							
TYPE OF SCREEN OR PERFORATION MATERIAL:		8 RMP (SR) 11 other (specify)							
1 Steel 3 Stainless Steel		5 Fiberglass 6 Concrete tile 9 ABS 12 None used (open hole)							
2 Brass 4 Galvanized steel		8 Saw cut 11 None (open hole)							
SCREEN OR PERFORATION OPENING ARE:		9 Drilled holes 10 Other (specify)							
1 Continuous slot 3 Mill slot		7 Torch cut							
2 Louvered shutter 4 Key punched		SCREEN-PERFORATION INTERVALS: from 25 ft. to 35 ft., From ft. to ft.							
GRAVEL PACK INTERVALS: from 20 ft. to 35 ft., From ft. to ft.		ft., From ft. to ft.							
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other bentonite hole plug		Grout Intervals: From 0 ft. to 20 ft. From ft. to ft. From ft. to ft.							
What is the nearest source of possible contamination:		10 Livestock pens 14 Abandon water well							
1 Septic tank 4 Lateral lines 7 Pit privy 11 Fuel storage 15 Oil well/Gas well		12 Fertilizer storage 16 Other (specify below)							
2 Sewer lines 5 Cess pool 8 Sewage lagoon 13 Insecticide storage None Apparent									
3 Watertight sewer lines 6 Seepage pit 9 Feedyard		Direction from well? How many feet?							
FROM TO LITHOLOGIC LOG FROM TO PLUGGING INTERVALS									
0 3 sandy topsoil									
3 22 black clay									
22 24 fine to medium sand									
24 35 medium to coarse sand									
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 03/07/1997 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236 This Water Well Record was completed on (mo/day/yr) 03/12/97									
Under the business name of Harp Well & Pump Service, Inc. by (signature) Todd S. Harp									