


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Sedgwick	Township name Riverside	Fraction NW$\frac{1}{4}$ NW$\frac{1}{4}$	Section number 3	Town number 28S	Range number 1E
Distance and direction from nearest town or city: 2516 N. Hydraulis			3 Owner of well: Melvin Mapes			
Street address of well location if in city: Wichita, Ks.			Address: 2516 Hydraulic Wichita, Kansas			
Locate with "X" in section below: N  S 1 Mile			Sketch map:			4 Well depth: 40 ft. Date of completion 5-22-75 Well diameter 11 in.
2 Type and color of material			From		To	
			Dirt and Sandy Soil		0	2
			Clay		2	11
			Medium Sand		11	23
			Clay and Shale		23	40
					5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary	
					6 Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☒ yard use	
					7 Casing: Material styrene Height: above/below Threaded ☐ Welded ☐ Surface 12 in. Diam. 5 in. to 40 ft. depth Drive shoe? ☐ Yes ☐ No 5 in. to 40 ft. depth	
					8 Screen: Manufacturer Sunflower Plastic Type styrene Dia. 5" Slot/gauze 005 Length 20' Set between 20 ft. and 40 ft. Fittings: Gravel pack ☒ Yes ☐ No Size range of material 1-1/8"	
					9 Static water level: 16 ft. below land surface Date 5-22-75	
					10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					11 Water sample submitted: ☐ Yes ☐ No Date ____	
					12 Well head completion: ☐ Pitless adapter 12 ☒ inches above grade	
					13 Well grouted? ☒ Yes ☐ No ☒ Neat cement ☐ Bentonite ☐ _____ Depth: From 0 ft. to 10 ft.	
					14 Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? ☒ Yes ☐ No	
					15 Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other	
16 Remarks: elevation Flat Ground No apparent source for contamination. Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. 67209 Address Wichita, Kansas Signed McConnell Date 5-22-75 Authorized representative	

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5