

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 SE 1/4 SE 1/4	Section number 16	Township number T 28 S	Range number R 1E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1501 East 45th South Wichita, Kansas			3. Owner of well: Vernon Richardson R.R. or street: 1501 East 45th South City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	
6. Bore hole dia. <u>11</u> in. Completion date <u>11-11-78</u> Well depth <u>40</u> ft.			7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☒ Lawn ☐ Oil field water ☐ Other			9. Casing: Material <u>Styrene</u> Height: Above or below Threaded ☐ Welded <u>gl</u> Surface <u>12</u> in. RMP ☒ PVC ☐ Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>40</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>.200</u>		
10. Screen: Manufacturer's name <u>Sunflower plastic</u> Type <u>styrene</u> Dia. <u>5"</u> Slot/ditch <u>.06</u> Length <u>17'</u> Set between <u>23</u> ft. and <u>40</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>			11. Static water level: <u>15</u> ft. below land surface Date <u>11-11-78</u> mo./day/yr.		
12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.			13. Water sample submitted: <u> </u> mo./day/yr. ☐ Yes ☐ No Date <u> </u>		
14. Well head completion: <u>12</u> capped <u> </u> Pitless adapter <u> </u> inches above grade			15. Well grouted? <u>yes</u> <u>1-2</u> fine sand mix With: <u> </u> Neat cement <u> </u> Bentonite ☒ Concrete Depth: From <u>40"</u> ft. to <u>14</u> ft.		
16. Nearest source of possible contamination: ft. <u>65</u> Direction <u>East</u> Type <u>Septic</u> Well disinfected upon completion? ☒ Yes <u>tank</u> No			17. Pump: ☒ Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other		
18. Elevation:			19. Remarks:		
Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley			Flat ground		
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Address Wichita, Kansas License No. 67209 Signed <u>M. Arnold</u> Date <u>12-4-78</u> Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5