

Sent 8/19/77

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NE SW NE SW

1. Location of well:		County <u>Sedgwick</u>	Fraction <u>NE 1/4 Sec 20</u>	Section number <u>20</u>	Township number <u>T 28</u>	Range number <u>S R 1</u>
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>5300 S Oak</u>				3. Owner of well: <u>Larrys Const</u> R.R. or street: <u>3300 S Oak</u> City, state, zip code: <u>Wichita KS</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date: <u>8/20/77</u> Well depth <u>25</u> ft.		
				7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
5. Type and color of material				8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other		
				9. Casing: Material <u>Styrene</u> Height Above or below Threaded ☐ Welded ☐ Surface <u>12</u> in. RMP ☐ PVC ☐ Weight <u>100</u> lbs./ft. Dia. <u>8</u> in. to <u>35</u> ft. depth Wall Thickness: inches or Dia. <u>8</u> in. to <u>35</u> ft. depth gage No. <u>100</u>		
				10. Screen: Manufacturer's name <u>Sunflower</u> Type <u>100</u> Dia. <u>4</u> Slot/gauze <u>Slot</u> Length <u>5</u> Set between <u>20</u> ft. and <u>25</u> ft. Set between <u>20</u> ft. and <u>25</u> ft. Gravel pack? <u>No</u> Size range of material <u>4</u>		
				11. Static water level: <u>10</u> ft. below land surface Date <u>7/18/77</u> mo./day/yr.		
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>10</u> g.p.m.		
				13. Water sample submitted: ____ mo./day/yr. Yes ☒ No ☐ Date ____		
				14. Well head completion: <u>12</u> inches above grade ____ Pitless adapter		
				15. Well grouted? <u>yes</u> With: ☒ Neat cement ☐ Bentonite ☐ Concrete Depth: From ____ ft. to ____ ft.		
				16. Nearest source of possible contamination: ft. <u>50</u> Direction <u>SOUTH</u> Type <u>SEWER</u> Well disinfected upon completion? ☒ Yes ☐ No		
				17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Jet Drilling 313</u> Business name License No. <u>557 N Sapin</u> Address <u>257 N Sapin</u> Signed <u>John Landrum</u> Date <u>8/18/77</u> Authorized representative		
Topography: ☐ Hill ☐ Slope ☒ Upland ☐ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5