

CORRECTION TO WATER WELL RECORD (WWC-5)

The following correction(s) was made to the attached WWC-5 log, in order to file the item or to rectify lacking or incorrect information.

Fraction (1/4 1/4 1/4) Section-Township-Range changed:

listed as 19-28S-1E

changed to NE NW NW, 30-28S-1E

Other changes: Initial statements:

Changed to:

Comments:

verification method: Well address on form, Wichita city map, and

Derby 1:24,000 topo map initials: RRL date: 10/11/2001


submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment Bureau of Water Industrial Programs, Bldg 283, Forbes Field, KS 66620

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Sedgwick	Township name Riverside	Fraction	Section number 19	Town number 28S	Range number 1E
Distance and direction from nearest town or city: 2005 West 55th S.				3 Owner of well: D.L. Slade		
Street address of well location if in city: Wichita, Kansas				Address: 2005 West 55th Street South Wichita, Kansas		
Locate with "X" in section below: 				Sketch map:		
2				4 Well depth: 52 ft. Date of completion 5-1-75 Well diameter 11 in.		
Type and color of material				5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
Dirt and Top Soil				6 Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐		
Clay				7 Casing: Material Styrene Height: above/below /// Threaded ☐ Welded ☐ Surface 12 in. Diam. 5 in. to 52 ft. depth Drive shoe? ☐ Yes ☐ No 5 in. to 52 ft. depth		
Medium Sand				8 Screen: Sunflower Plastic Manufacturer Styrene Dia. 5" Type Styrene Slot/gauze .005 Length 10' Set between 42 ft. and 52 ft. Fittings: Gravel pack ☒ Yes ☐ No Size range of material 1-1/8"		
				9 Static water level: 15 ft. below land surface Date 5-1-75		
				10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
				11 Water sample submitted: ☐ Yes ☐ No Date ____		
				12 Well head completion: ☒ Pitless adapter 12 ☒ Inches above grade		
				13 Well grouted? ☒ Yes ☐ No ☒ Neat cement ☐ Bentonite ☐ Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: ft. 70 Direction South Type Septic Well disinfected upon completion? ☒ Yes ☐ No		
				15 Pump: ☐ Not installed Manufacturer's name Sta-Rite Model number LP6D2 HP 3/4 Volts 230 Length of drop pipe 30 ft. capacity 20 g.m.p. Type: ☒ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other		
(use a second sheet if needed)						
16 Remarks: elevation Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. 67209 Address Wichita, Kansas Signed M. Ansell Date 5-6-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5