

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Sedgwick</u>		Fraction <u>SW 1/4 SW 1/4</u>	Section number <u>21</u>	Township number <u>T 28 S</u>	Range number <u>R 1 E</u>
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>5330 S. Broadway</u> <u>Wichita, Kansas</u>		3. Owner of well: <u>Ronald Evans</u> Street: <u>5330 S. Broadway</u> City, state, zip code: <u>Wichita, Kansas</u>			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: 6. Bore hole dia. <u>11</u> in. Completion date <u>2-17-76</u> Well depth <u>40</u> ft. 7. ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary 8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other 9. Casing: Material <u>styrofoam</u> Height <u>above</u> or below Threaded ☐ Welded ☒ Surface <u>12</u> in. RMP ☒ PVC ☐ Weight <u>1</u> lbs./ft. Dia. <u>5</u> in. to <u>40</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>40</u> ft. depth gage No. <u>2200</u>			
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>Sunflower Plastic</u> Type <u>styrofoam</u> Dia. <u>5"</u> Net/gauze <u>0.06</u> Length <u>15'</u> Set between <u>25</u> ft. and <u>40</u> ft. Gravel pack? <u>yes</u> size range of material <u>1/4"-1/8"</u>	
<u>Topsoil</u>		<u>0</u>	<u>4</u>	11. Static water level: <u>17</u> ft. below land surface Date <u>2-17-76</u>	
<u>Brown clay</u>		<u>4</u>	<u>16</u>	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
<u>Medium Sand</u>		<u>16</u>	<u>25</u>	13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____	
<u>Coarse sand</u>		<u>25</u>	<u>38</u>	14. Well head completion: <u>12</u> Capped Pitless adapter ____ inches above grade	
<u>Gray clay</u>		<u>38</u>	<u>40</u>	15. Well grouted: <u>yes</u> With: <u>Neat cement</u> ☐ Bentonite ☒ Concrete Depth: From <u>40'</u> to <u>14'</u> ft.	
				16. Nearest source of possible contamination: <u>Septic Tank</u> ft. <u>125</u> Direction <u>NORTH</u> Type <u>Tank</u> Well disinfected upon completion? ☒ Yes ____ No	
				17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other	
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Harshwell Pump 236</u> Business name <u>Wichita, Kansas</u> License No. ____ Address <u>Wichita, Kansas</u> Signed <u>D. Arnold</u> Date <u>2-20-76</u> Authorized representative	
19. Remarks: <u>Flat Ground</u>					
Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5