


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Sedgwick	Township name Riverside	Fraction SW 1/4 Ne 1/4	Section number 26	Town number 28S	Range number 1E		
Distance and direction from nearest town or city: 902 East 59th So.			3 Owner of well: Wesley Kramer					
Street address of well location if in city: Wichita, Kansas			Address: 902 East 59th Street South Wichita, Kansas					
Locate with "X" in section below: 			Sketch map: 			4 Well depth: 56 ft. Date of completion 5-28-75 Well diameter 11 in.		
2 Type and color of material			5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary					
			6 Use: ☐ Domestic ☐ Public supply ☐ Industry ☒ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐ yard use					
			7 Casing: Material styrene Height: above/below 11 in. Threaded ☐ Welded ☐ Surface ☐ 12 in. Diam. 5 in. to 56 ft. depth Weight 56 lbs./ft. Drive shoe? ☐ Yes ☐ No					
			8 Screen: Manufacturer Sunflower Plastic Type styrene Dia. 5" Slot/gauze .005 Length 20' Set between 36 ft. and 56 ft. Fittings: Gravel pack ☒ Yes ☐ No Size range of material 1-1/8"					
			9 Static water level: 16 ft. below land surface Date 5-28-75					
(use a second sheet if needed)			10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.					
			11 Water sample submitted: ☐ Yes ☐ No Date ____					
			12 Well head completion: capped ☐ Pitless adapter 12 ☒ Inches above grade					
			13 Well grouted? ☒ Yes ☐ No ☒ Neat cement ☐ Bentonite ☐ Depth: From 0 ft. to 10 ft.					
			14 Nearest source of possible contamination: ft. 75 Direction SE Type Septic tank Well disinfected upon completion? ☒ Yes ☐ No					
16 Remarks: elevation Flat Ground Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley			15 Pump: ☒ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity ____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other					
			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. 67209 Address 2nd Arnold Signed 5-28-75 Authorized representative					

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5